




PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
FLENDER CAMPGEAR 2
 Component
Reduction Gear
 Fluid
FUCHS RENOLIN CLP ISO 320 (220 LTR)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 22624	▲ 47589	● 180772
Particles >6µm	ASTM D7647	>5000	▲ 7917	▲ 13766	● 53429
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 22/20/16	▲ 23/21/17	● 25/23/19

Customer Id: PET412PET
 Sample No.: WC119385
 Lab Number: 02337343
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Wes Davis +1 905-569-8600 x223
wesd@wearcheck.ca

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Mar 03 2020	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

20 Jan 2020 Diag: Kevin Marson

VISCOSITY



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



18 Nov 2019 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. The oil change at the time of sampling has been noted. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
FLENDER CAMPGEAR 2
 Component
Reduction Gear
 Fluid
FUCHS RENOLIN CLP ISO 320 (220 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC119385	WC0423448	WC119397
Sample Date	Client Info		04 Feb 2020	20 Jan 2020	18 Nov 2019
Machine Age	hrs	Client Info	191554	195782	189711
Oil Age	hrs	Client Info	2034	1698	191
Oil Changed	Client Info		Not Chngd	Filtered	Changed
Sample Status			ATTENTION	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >150	1	2	3
Chromium	ppm	ASTM D5185(m) >10	<1	<1	<1
Nickel	ppm	ASTM D5185(m) >10	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	0	0
Aluminum	ppm	ASTM D5185(m) >25	<1	0	<1
Lead	ppm	ASTM D5185(m) >100	0	0	0
Copper	ppm	ASTM D5185(m) >50	<1	<1	1
Tin	ppm	ASTM D5185(m) >10	0	0	0
Antimony	ppm	ASTM D5185(m)	<1	<1	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	6	7	6
Barium	ppm	ASTM D5185(m)	<1	<1	<1
Molybdenum	ppm	ASTM D5185(m)	5	5	4
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	7	7	7
Calcium	ppm	ASTM D5185(m)	<1	<1	<1
Phosphorus	ppm	ASTM D5185(m)	313	314	307
Zinc	ppm	ASTM D5185(m)	20	20	18
Sulfur	ppm	ASTM D5185(m)	5288	5349	5176
Lithium	ppm	ASTM D5185(m)	1	1	2

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	6	6	3
Sodium	ppm	ASTM D5185(m)	0	0	0
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 22624	▲ 47589	● 180772
Particles >6µm	ASTM D7647	>5000	▲ 7917	▲ 13766	● 53429
Particles >14µm	ASTM D7647	>640	593	▲ 1045	▲ 3012
Particles >21µm	ASTM D7647	>160	167	▲ 346	▲ 826
Particles >38µm	ASTM D7647	>40	3	14	28
Particles >71µm	ASTM D7647	>10	0	2	3
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 22/20/16	▲ 23/21/17	● 25/23/19

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.452	0.510	0.498




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	320	314	316	309

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC119385 **Received** : 11 Feb 2020
Lab Number : 02337343 **Diagnosed** : 11 Feb 2020
Unique Number : 5004762 **Diagnostician** : Wes Davis
Test Package : IND 2 (Additional Tests: TAN Man)

PETERBOROUGH UTILITIES INC
 1867 ASHBURNHAM DRIVE
 PETERBOROUGH, ON
 CA K9L 1P8
 Contact: Nelson Ross
 nross@pui.ca
 T: (705)760-6119
 F: (705)748-3138