




PROBLEM SUMMARY

Sample Rating Trend



DEGRADATION



Machine Id
NORTHERN GS1-T2
 Component
Transformer Oil
 Fluid
MIDEZ 1204 (4966 LTR)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We recommend an early resample to monitor this condition. No other corrective action is recommended at this time. NOTE: No sample syringe was received so Dissolved Gas Analysis (DGA) could not be carried out.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	---	---
Interfacial Tension	mN/m	ASTM D971(e)*	▲ 27.26	---	---

Customer Id: ENE271OTT
Sample No.: WC0475700
Lab Number: 02375365
Test Package: TRF 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1
 (289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION



Machine Id
NORTHERN GS1-T2
 Component
Transformer Oil
 Fluid
MIDEZ 1204 (4966 LTR)

DIAGNOSIS

Recommendation

We recommend an early resample to monitor this condition. No other corrective action is recommended at this time. NOTE: No sample syringe was received so Dissolved Gas Analysis (DGA) could not be carried out.

Wear

{not applicable}

Contamination

There is no indication of any contamination in the transformer oil.

Fluid Condition

The Interfacial Tension (ASTM D971) is low at 27.26 dynes/cm.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0475700	---	---
Sample Date	Client Info	04 Sep 2020	---	---
Machine Age	hrs	Client Info	0	---
Oil Age	hrs	Client Info	0	---
Oil Changed	Client Info	N/A	---	---
Sample Status		ABNORMAL	---	---

CONTAMINANTS

method	limit/base	current	history1	history2	
Water	%	ASTM D6304*	0.007	---	---
ppm Water	ppm	ASTM D6304*	0	---	---

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	1373	---	---
Particles >6µm	ASTM D7647	>1300	535	---	---
Particles >14µm	ASTM D7647	>160	44	---	---
Particles >21µm	ASTM D7647	>40	14	---	---
Particles >38µm	ASTM D7647	>10	1	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	18/16/13	---	---

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.06	---	---

VISUAL

method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---

FLUID PROPERTIES





method	limit/base	current	history1	history2	
Specific Gravity	ASTM D4052(e)		0.928	---	---
Dielectric Breakdown	kV	ASTM D3612(e)*	68	---	---
Interfacial Tension	mN/m	ASTM D971(e)*	▲ 27.26	---	---
ASTM Color	scalar	ASTM D1500(e)	0.5	---	---

SAMPLE IMAGES





method	limit/base	current	history1	history2
Color			no image	no image
Bottom			no image	no image



OIL ANALYSIS REPORT



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Chaudiere Hydro LP - Energy Ottawa**
Sample No. : WC0475700 **Received** : 11 Sep 2020 4 Booth Street
Lab Number : 02375365 **Diagnosed** : 13 Oct 2020 Ottawa, ON
Unique Number : 5098813 **Diagnostician** : Bill Quesnel CA K1R 6K8
Test Package : TRF 2 (Additional Tests: PrtCount) Contact: Cheryl Gharib

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
 F: x