




PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
[178362]
 Machine Id
HCT-G-UGBR/THBR
 Component
Bearing
 Fluid
ESSO TERESSO ISO 68 (95 GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | ATTENTION | ABNORMAL | ABNORMAL |
|-----------------|------------------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 >10000 | ▲ 17175 | ▲ 44202 | ▲ 58568 |
| Oil Cleanliness | ISO 4406 (c) >20/18/14 | ▲ 21/18/13 | ▲ 23/19/14 | ▲ 23/20/14 |

Customer Id: NEWSTJ
 Sample No.: WC0327950
 Lab Number: 02381786
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|-------------|---------|---|
| Change Filter | MISSED | Sep 03 2021 | ? | We recommend you service the filters on this component. |

HISTORICAL DIAGNOSIS

09 Dec 2019 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



22 Aug 2019 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



17 Dec 2018 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
[178362]
 Machine Id
HCT-G-UGBR/THBR
 Component
Bearing
 Fluid
ESSO TERESSO ISO 68 (95 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0327950 | WC0299315 | WC0299360 |
| Sample Date | Client Info | | 01 Sep 2020 | 09 Dec 2019 | 22 Aug 2019 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ATTENTION | ABNORMAL | ABNORMAL |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >2 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 | |
|-----------|--------|---------------|---------|--------------|----------|----|
| Iron | ppm | ASTM D5185(m) | >63 | <1 | <1 | <1 |
| Chromium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | | <1 | <1 | 0 |
| Titanium | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Silver | ppm | ASTM D5185(m) | | <1 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) | >2 | <1 | <1 | 0 |
| Lead | ppm | ASTM D5185(m) | >161 | 3 | <1 | <1 |
| Copper | ppm | ASTM D5185(m) | >13 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185(m) | >27 | 2 | 2 | 2 |
| Antimony | ppm | ASTM D5185(m) | | 0 | <1 | <1 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 | |
|------------|--------|---------------|---------|--------------|----------|------|
| Boron | ppm | ASTM D5185(m) | 4.5 | <1 | <1 | 0 |
| Barium | ppm | ASTM D5185(m) | 0.4 | <1 | <1 | <1 |
| Molybdenum | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) | 0 | <1 | <1 | 0 |
| Calcium | ppm | ASTM D5185(m) | 0 | 1 | 1 | 1 |
| Phosphorus | ppm | ASTM D5185(m) | 0.7 | 3 | 2 | 2 |
| Zinc | ppm | ASTM D5185(m) | 0 | 3 | 2 | 2 |
| Sulfur | ppm | ASTM D5185(m) | 1315 | 1921 | 1875 | 1879 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |

CONTAMINANTS





| | method | limit/base | current | history1 | history2 | |
|-----------|--------|---------------|---------|--------------|----------|----|
| Silicon | ppm | ASTM D5185(m) | >12 | 6 | 4 | 6 |
| Sodium | ppm | ASTM D5185(m) | | <1 | 0 | 0 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |

FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 | >10000 | ▲ 17175 | ▲ 44202 | ▲ 58568 |
| Particles >6µm | ASTM D7647 | >2500 | 1915 | ▲ 4241 | ▲ 5791 |
| Particles >14µm | ASTM D7647 | >160 | 76 | 82 | 116 |
| Particles >21µm | ASTM D7647 | >40 | 20 | 20 | 25 |
| Particles >38µm | ASTM D7647 | >10 | 1 | 1 | 0 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/18/14 | ▲ 21/18/13 | ▲ 23/19/14 | ▲ 23/20/14 |



OIL ANALYSIS REPORT



| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.02 | 0.12 | 0.077 | 0.086 |





| VISUAL | | method | limit/base | current | history1 | history2 |
|------------------|--------|---------|------------|--------------|----------|----------|
| White Metal | scalar | Visual* | NONE | NONE | VLITE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Debris | scalar | Visual* | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | >2 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |

| FLUID PROPERTIES | | method | limit/base | current | history1 | history2 |
|------------------|-----|---------------|------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 68 | 68.4 | 68.8 | 68.5 |

| SAMPLE IMAGES | | method | limit/base | current | history1 | history2 |
|---------------|--|--------|------------|---------|----------|----------|
|---------------|--|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0327950
Lab Number : 02381786
Unique Number : 5121240
Test Package : IND 2 (Additional Tests: TAN Man)

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com
 T:
 F: (709)737-2926

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.