




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
PNETECH CAMPTUR1LUB

Component
Turbine
Fluid
PETRO CANADA HARMONY R&O 32 (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.
NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0423444	WC0373484	---
Sample Date	Client Info		17 Dec 2020	05 Dec 2019	---
Machine Age	hrs	Client Info	100882	194203	---
Oil Age	hrs	Client Info	9262	71763	---
Oil Changed		Client Info	N/A	N/A	---
Sample Status			NORMAL	ATTENTION	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >15	<1	<1	---
Chromium	ppm	ASTM D5185(m) >4	0	0	---
Nickel	ppm	ASTM D5185(m) >2	0	<1	---
Titanium	ppm	ASTM D5185(m)	0	0	---
Silver	ppm	ASTM D5185(m)	<1	0	---
Aluminum	ppm	ASTM D5185(m) >10	<1	0	---
Lead	ppm	ASTM D5185(m)	<1	0	---
Copper	ppm	ASTM D5185(m) >5	<1	<1	---
Tin	ppm	ASTM D5185(m) >5	0	0	---
Antimony	ppm	ASTM D5185(m)	0	<1	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	---
Barium	ppm	ASTM D5185(m)	0	0	---
Molybdenum	ppm	ASTM D5185(m)	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	---
Magnesium	ppm	ASTM D5185(m)	<1	<1	---
Calcium	ppm	ASTM D5185(m)	<1	<1	---
Phosphorus	ppm	ASTM D5185(m)	4	2	---
Zinc	ppm	ASTM D5185(m)	2	<1	---
Sulfur	ppm	ASTM D5185(m)	35	16	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	1	<1	---
Sodium	ppm	ASTM D5185(m)	2	<1	---
Potassium	ppm	ASTM D5185(m) >20	<1	<1	---
Water	%	ASTM D6304* >0.03	0.001	0.00	---
ppm Water	ppm	ASTM D6304* >300	8.9	0.00	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	257	▲ 4452	---
Particles >6µm	ASTM D7647	>640	48	▲ 1054	---
Particles >14µm	ASTM D7647	>80	4	31	---
Particles >21µm	ASTM D7647	>20	1	8	---
Particles >38µm	ASTM D7647	>4	0	0	---
Particles >71µm	ASTM D7647	>3	0	0	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	15/13/9	▲ 19/17/12	---



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		0.12	0.130	---






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.03	NEG	NEG	---
Free Water	scalar	Visual*		NEG	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		32.2	32.6	---

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0423444
Lab Number : **02394793**
Unique Number : 5150251
Test Package : IND 2

PETERBOROUGH UTILITIES INC
 1867 ASHBURNHAM DRIVE
 PETERBOROUGH, ON
 CA K9L 1P8
 Contact: Nelson Ross
 nross@pui.ca
 T: (705)760-6119
 F: (705)748-3138

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.