

OIL ANALYSIS REPORT

Sample Rating Trend



SST2BDE Component

Transformer Oil

NOT GIVEN (297 LTR)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The water content is negligible.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the transformer oil is suitable for further service.

SAMPLE INFORM	MATION		May2020	Jan2021	la i a ta mud	، سوماد ال
	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0380014	WC0380020	
Sample Date		Client Info		12 Jan 2021	25 May 2020	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
CONTAMINANTS		method	limit/base	current	history1	history2
Water	%	ASTM D6304*	>0.0035	0.001	0.002	
opm Water	ppm	ASTM D6304*	>35	0	0	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	240	2377	
Particles >6µm		ASTM D7647	>1300	60	634	
Particles >14µm		ASTM D7647	>160	6	55	
Particles >21µm		ASTM D7647	>40	2	19	
Particles >38µm		ASTM D7647	>10	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	15/13/10	18/16/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		0.02	0.02	
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	
Silt	scalar	Visual*	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	NONE	
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	
Odor	scalar	Visual*	NORML	NORML	NORML	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D4052(e)		0.856	0.859	
Dielectric Breakdown	kV	ASTM D3612(e)*		37	42	
Interfacial Tension	mN/m	ASTM D971(e)*		34.4	36.58	
ASTM Color	scalar	ASTM D1500(e)		1.0	1.0	
SAMPLE IMAGES	5	method	limit/base	current	history1	history2
Color						no image
Bottom						no image



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number

: WC0380014

: 5224570

Received : 02421070

: 12 May 2021 Diagnosed : 26 May 2021 Diagnostician : Bill Quesnel

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 NEWFOUNDLAND & LABRADOR HYDRO BAY D'ESPOIR WHSE,, 1 CAMP BOGGY RD., PO BOX 100 MILLTOWN, BAY D'ESPOIR, NL

CA A0H 1W0 Test Package : TRF 1 (Additional Tests: PrtCount) Contact: Matthew Lambert To discuss this sample report, contact Customer Service at 1-800-268-2131. matthewlambert@nlh.nl.ca T: (709)882-3126

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

F: (709)882-3161