




# PROBLEM SUMMARY

## Sample Rating Trend

WATER




Area  
**EAR FALLS GS**  
 Machine Id  
**FP1G4**  
 Component  
**Thrust Bearing**  
 Fluid  
**R&O OIL ISO 46 (--- GAL)**



## COMPONENT CONDITION SUMMARY

### Particle Trend




## RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) R&O OIL ISO 46. Please confirm. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	ABNORMAL
Particles >4µm	ASTM D7647	>10000	SEVERE 89850	99848	62451
Particles >6µm	ASTM D7647	>2500	SEVERE 19736	17506	4521
Particles >14µm	ASTM D7647	>160	SEVERE 849	247	33
Particles >21µm	ASTM D7647	>40	SEVERE 172	41	5
Oil Cleanliness	ISO 4406 (c)	>20/18/14	SEVERE 24/21/17	24/21/15	23/19/12
White Metal	scalar Visual*	NONE	VLITE	VLITE	NONE
Free Water	scalar Visual*		.2%	NEG	NEG

PrtFilter



Customer Id: ONTKEE  
 Sample No.: WC0560613  
 Lab Number: 02423561  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Alert	---	---	?	Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 07 Jul 2020 Diag: Kevin Marson

DIRT



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Light concentration of visible metal present. Particles >4µm are severely high. Particles >4µm are severely high.. Particles >6µm are abnormally high. Particles >14µm are notably high. Light concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 08 May 2019 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 01 Feb 2018 Diag: Bill Quesnel

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. MPC (Membrane Patch Calorimetry) test indicates acceptable levels of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. Water Separability results (ASTM D1401) indicate good water shedding properties. The system and fluid cleanliness is acceptable. The Air Release Value (ASTM D3427) indicates that the oil has good deaeration properties. Foaming Tendency and Stability (ASTM D892) results all within normal range. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil. The Rotating Pressure Vessel Oxidation Test (RPVOT – ASTM D2272) result indicates suitable amounts of anti-oxidant(s) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Area  
**EAR FALLS GS**  
 Machine Id  
**FP1G4**  
 Component  
**Thrust Bearing**  
 Fluid  
**R&O OIL ISO 46 (--- GAL)**



## DIAGNOSIS

### Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) R&O OIL ISO 46. Please confirm. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

Light concentration of visible metal present.

### Contamination

Particles >4µm are severely high. Particles >4µm are severely high.. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >6µm are abnormally high. Free water present.

### Fluid Condition

The AN level is acceptable for this fluid.

Particle Filter (Magn: 200 x)



## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0560613</b>	WC0481701	WC0335054
Sample Date	Client Info	<b>03 May 2021</b>	07 Jul 2020	08 May 2019
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185(m)	>85	<b>6</b>	4	4
Chromium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>40	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m)	>60	<b>1</b>	1	1
Copper	ppm	ASTM D5185(m)	>7	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185(m)	>40	<b>&lt;1</b>	<1	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	<1	<1

## ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	<1	<1
Barium	ppm	ASTM D5185(m)	5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	5	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	<1	<1
Phosphorus	ppm	ASTM D5185(m)	100	<b>&lt;1</b>	<1	<1
Zinc	ppm	ASTM D5185(m)	25	<b>&lt;1</b>	2	<1
Sulfur	ppm	ASTM D5185(m)	1500	<b>2198</b>	2215	2191
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	0

## CONTAMINANTS






method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185(m)		<b>0</b>	<1	0
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Water	%	ASTM D6304*	>2	<b>0.001</b>	---	---
ppm Water	ppm	ASTM D6304*		<b>12.8</b>	---	---

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>10000	<b>89850</b>	99848	62451
Particles >6µm	ASTM D7647	>2500	<b>19736</b>	17506	4521
Particles >14µm	ASTM D7647	>160	<b>849</b>	247	33
Particles >21µm	ASTM D7647	>40	<b>172</b>	41	5
Particles >38µm	ASTM D7647	>10	<b>9</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	<b>24/21/17</b>	24/21/15	23/19/12



# OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.08	<b>0.05</b>	0.12	0.109
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	▲ VLITE	▲ VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	▲ VLITE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>2	<b>.2%</b>	NEG	NEG
Free Water	scalar	Visual*		▲ <b>.2%</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	<b>46.4</b>	46.5	46.4

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						
PrtFilter						
MPC						



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0560613 **Received** : 26 May 2021  
**Lab Number** : **02423561** **Diagnosed** : 27 May 2021  
**Unique Number** : 5227061 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: BottomAnalysis, FilterPatch, KF, PrtCount )

**Ontario Power Generation**  
 KENORA PRODUCTION CENTRE, 200-60 FOURTEENTH ST. N.  
 KENORA, ON  
 CA P9N 4M9  
 Contact: Josh Robinson  
 josh.robinson@opg.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.