



# PROBLEM SUMMARY

Sample Rating Trend

WEAR



Area

8

Machine Id


## 8-2-301-B FM #2 Trunion - Feed End

Component

Journal Bearing


Fluid

MOBIL MOBILGEAR SHC 460 (350 LTR)




### COMPONENT CONDITION SUMMARY

#### ▲ Non-ferrous Metals



#### ▲ Additives



### RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

### PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	NORMAL
Tin	ppm	ASTM D5185(m)	>80	▲ 124	40	32
Antimony	ppm	ASTM D5185(m)		▲ 17	4	3
Phosphorus	ppm	ASTM D5185(m)	180	▲ 453	222	181
Sulfur	ppm	ASTM D5185(m)	4270	▲ 5033	4051	3591

Customer Id: STMBOW  
Sample No.: WC0627342  
Lab Number: 02455193  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	MISSED	Nov 19 2021	?	We recommend an early resample to monitor this condition.
Check Fluid Source	MISSED	Nov 19 2021	?	Confirm the source of the lubricant being utilized for top-up/fill.

## HISTORICAL DIAGNOSIS

### 06 Jul 2021 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 15 Apr 2021 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Jan 2021 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





# OIL ANALYSIS REPORT

Sample Rating Trend

WEAR



Area

8

Machine Id


## 8-2-301-B FM #2 Trunion - Feed End

Component

Journal Bearing

Fluid

MOBIL MOBILGEAR SHC 460 (350 LTR)



### DIAGNOSIS

#### Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

#### Wear

Tin and antimony ppm levels are abnormal. A sharp increase in the tin level is noted. A sharp increase in the antimony level is noted. Bearing wear is indicated.

#### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

#### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0627342	WC0600017	WC0568166
Sample Date	Client Info		19 Oct 2021	06 Jul 2021	15 Apr 2021
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	NORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>60	11	8
Chromium	ppm	ASTM D5185(m)		0	0
Nickel	ppm	ASTM D5185(m)		<1	<1
Titanium	ppm	ASTM D5185(m)		0	0
Silver	ppm	ASTM D5185(m)		<1	<1
Aluminum	ppm	ASTM D5185(m)	>4	1	2
Lead	ppm	ASTM D5185(m)	>250	7	2
Copper	ppm	ASTM D5185(m)	>125	8	6
Tin	ppm	ASTM D5185(m)	>80	▲ 124	40
Antimony	ppm	ASTM D5185(m)		▲ 17	4
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	5.7	11	7
Barium	ppm	ASTM D5185(m)	0.0	0	0
Molybdenum	ppm	ASTM D5185(m)	0.0	0	0
Manganese	ppm	ASTM D5185(m)	0.0	0	<1
Magnesium	ppm	ASTM D5185(m)	0.0	1	1
Calcium	ppm	ASTM D5185(m)	0.0	28	19
Phosphorus	ppm	ASTM D5185(m)	180	▲ 453	222
Zinc	ppm	ASTM D5185(m)	0.8	<1	2
Sulfur	ppm	ASTM D5185(m)	4270	▲ 5033	4051
Lithium	ppm	ASTM D5185(m)		<1	<1

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	7	11
Sodium	ppm	ASTM D5185(m)		<1	0
Potassium	ppm	ASTM D5185(m)	>20	2	2


### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		176114	233616	233836
Particles >6µm	ASTM D7647	>320000	134046	143651	127947
Particles >14µm	ASTM D7647	>160000	12309	3985	3814
Particles >21µm	ASTM D7647	>40000	202	127	109
Particles >38µm	ASTM D7647	>10000	0	1	0
Particles >71µm	ASTM D7647	>2500	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/25/24	25/24/21	25/24/19	25/24/19


### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.38	0.75	0.67


### Additives




### Particle Trend




### Particle Count



### Acid Number




### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	LIGHT	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	LTMOD
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	477	463	485

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### Particle Count



#### Acid Number



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0627342 **Received** : 09 Nov 2021  
**Lab Number** : 02455193 **Diagnosed** : 11 Nov 2021  
**Unique Number** : 5306731 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: TAN Man )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**ST. MARYS CEMENT CO.**  
 400 BOWMANVILLE AVENUE  
 BOWMANVILLE, ON  
 CA L1C 7B5  
 Contact: Aleksandrs Cascins  
 Alex.Cascins@vcimentos.com  
 T: (905)623-3341  
 F: (905)623-4695