




OIL ANALYSIS REPORT

Sample Rating Trend



PH



Machine Id
AGENITOR G4789
 Component
Right Natural Gas Engine
 Fluid
SHELL MYSELLA S5 S (--- LTR)

DIAGNOSIS

▲ Recommendation

We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

▲ Fluid Condition

The i-pH level is abnormally low. The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0546682	WC0546681	WC101545
Sample Date	Client Info		13 Jan 2022	29 Jun 2021	22 Jan 2020
Machine Age	hrs	Client Info	25014	22471	12521
Oil Age	hrs	Client Info	1011	986	276
Oil Changed	Client Info		N/A	Not Changd	Changed
Sample Status			ABNORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	6	3	4
Chromium	ppm	ASTM D5185(m)	>4	<1	<1	1
Nickel	ppm	ASTM D5185(m)	>2	<1	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	<1
Silver	ppm	ASTM D5185(m)	>3	0	0	0
Aluminum	ppm	ASTM D5185(m)	>9	3	2	1
Lead	ppm	ASTM D5185(m)	>30	<1	<1	0
Copper	ppm	ASTM D5185(m)	>35	3	9	1
Tin	ppm	ASTM D5185(m)	>4	<1	0	0
Antimony	ppm	ASTM D5185(m)		<1	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		2	3	4
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		1	2	5
Manganese	ppm	ASTM D5185(m)		<1	<1	<1
Magnesium	ppm	ASTM D5185(m)		7	8	5
Calcium	ppm	ASTM D5185(m)		1864	1740	1727
Phosphorus	ppm	ASTM D5185(m)	300	319	288	279
Zinc	ppm	ASTM D5185(m)		389	368	344
Sulfur	ppm	ASTM D5185(m)		2368	2681	2501
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>+100	84	8	71
Sodium	ppm	ASTM D5185(m)		<1	1	0
Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1

INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	6.8	5.9	5.8
Sulfation	Abs/.1mm	ASTM D7415*	>30	20.5	18.5	21.1

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	14.8	12.2	11.2
Acid Number (AN)	mg KOH/g	ASTM D974*		2.01	1.67	1.29
Base Number (BN)	mg KOH/g	ASTM D2896*	5.3	4.14	4.43	4.84
i-pH	Scale 0-14	ASTM D7946*	<4.5	▲ 3.72	5.13	5.2











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	13.5	14.4	13.7

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0546682 **Received** : 18 Jan 2022
Lab Number : 02466514 **Diagnosed** : 18 Jan 2022
Unique Number : 5343432 **Diagnostician** : Kevin Marson
Test Package : MOB 2 (Additional Tests: i-pH, TAN Auto, TAN Man)

CHATHAM-KENT PUC
 100 IRWIN ST
 CHATHAM, ON
 CA N7M 5K8
 Contact: Ken McCracken
 kenmc@chatham-kent.ca
 T: (519)352-1971
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.