




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
MOBILE DIESEL - MD3 (S/N 528100145)

Component
Diesel Engine

Fluid
PETRO CANADA DURON HP 15W40 (340 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0445191	WC0328046	WC0327975
Sample Date	Client Info	15 Dec 2021	10 Jun 2021	26 Oct 2020
Machine Age	hrs Client Info	0	0	0
Oil Age	hrs Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >3.0	<1.0	<1.0	<1.0
Water	WC Method >0.2	NEG	NEG	NEG
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m) >200	20	15	7
Chromium	ppm ASTM D5185(m) >6	2	1	<1
Nickel	ppm ASTM D5185(m) >4	<1	<1	0
Titanium	ppm ASTM D5185(m)	0	0	0
Silver	ppm ASTM D5185(m)	0	0	0
Aluminum	ppm ASTM D5185(m) >30	2	2	1
Lead	ppm ASTM D5185(m) >30	2	1	<1
Copper	ppm ASTM D5185(m) >30	4	3	2
Tin	ppm ASTM D5185(m) >10	<1	<1	<1
Antimony	ppm ASTM D5185(m)	0	<1	0
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 0	2	2	2
Barium	ppm ASTM D5185(m) 0	0	<1	<1
Molybdenum	ppm ASTM D5185(m) 60	74	69	63
Manganese	ppm ASTM D5185(m) 0	<1	<1	<1
Magnesium	ppm ASTM D5185(m) 1010	1289	1198	1085
Calcium	ppm ASTM D5185(m) 1070	1299	1245	1156
Phosphorus	ppm ASTM D5185(m) 1150	1213	1156	1064
Zinc	ppm ASTM D5185(m) 1270	1486	1415	1346
Sulfur	ppm ASTM D5185(m) 2060	2774	2675	2765
Lithium	ppm ASTM D5185(m)	<1	<1	<1

CONTAMINANTS



method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >30	4	3	3
Sodium	ppm ASTM D5185(m)	2	2	2
Potassium	ppm ASTM D5185(m) >20	0	<1	0

INFRA-RED

method	limit/base	current	history1	history2
Soot %	% ASTM D7844* >3	0.1	0	0.1
Nitration	Abs/cm ASTM D7624* >20	8.6	7.8	6.8
Sulfation	Abs/.1mm ASTM D7415* >30	22.1	20.3	19.4



OIL ANALYSIS REPORT











FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	ASTM D7414*	>25	17.9	16.5	15.0
Base Number (BN)	mg KOH/g	ASTM D2896*	9.8	12.35	11.56	11.67

VISUAL	method	limit/base	current	history1	history2	
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D7279(m)	15.6	15.8	15.4	14.7

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0445191 **Received** : 20 Jan 2022
Lab Number : **02467151** **Diagnosed** : 21 Jan 2022
Unique Number : 5344069 **Diagnostician** : Wes Davis
Test Package : MOB 2

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com
 T:
 F: (709)737-2926

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.