




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
KEN DIESEL (S/N 4RG01618)
 Component
Diesel Engine
 Fluid
CAT DIESEL ENGINE OIL 15W40 (34 LTR)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0445330	WC0328050	WC0327968
Sample Date	Client Info		03 Mar 2022	27 May 2021	16 Jun 2020
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	<1.0
Water	WC Method	>0.2	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>100	46	44	59
Chromium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Nickel	ppm	ASTM D5185(m)	>2	<1	<1	1
Titanium	ppm	ASTM D5185(m)	>2	0	0	<1
Silver	ppm	ASTM D5185(m)	>2	0	<1	<1
Aluminum	ppm	ASTM D5185(m)	>25	2	2	2
Lead	ppm	ASTM D5185(m)	>40	4	4	5
Copper	ppm	ASTM D5185(m)	>330	20	19	28
Tin	ppm	ASTM D5185(m)	>15	2	2	2
Antimony	ppm	ASTM D5185(m)		<1	<1	<1
Vanadium	ppm	ASTM D5185(m)		0	0	<1
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		<1	<1	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		34	35	44
Barium	ppm	ASTM D5185(m)		3	3	4
Molybdenum	ppm	ASTM D5185(m)		16	16	4
Manganese	ppm	ASTM D5185(m)		<1	<1	<1
Magnesium	ppm	ASTM D5185(m)		657	659	606
Calcium	ppm	ASTM D5185(m)		1562	1557	1821
Phosphorus	ppm	ASTM D5185(m)		1005	1012	1043
Zinc	ppm	ASTM D5185(m)	1460	1176	1196	1287
Sulfur	ppm	ASTM D5185(m)		3276	3353	3874
Lithium	ppm	ASTM D5185(m)		0	<1	<1

CONTAMINANTS



	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>25	8	7	9
Sodium	ppm	ASTM D5185(m)		6	6	7
Potassium	ppm	ASTM D5185(m)	>20	1	2	2

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*	>3	0.2	0.2	0.4
Nitration	Abs/cm	ASTM D7624*	>20	8.3	8.2	10.1
Sulfation	Abs./1mm	ASTM D7415*	>30	23.5	22.0	27.9



OIL ANALYSIS REPORT











FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	16.4	16.7	16.8
Base Number (BN)	mg KOH/g	ASTM D2896*	11.3	7.31	7.63	7.33

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	15.5	13.2	13.1	13.2

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0445330 **Received** : 04 Apr 2022
Lab Number : **02481044** **Diagnosed** : 05 Apr 2022
Unique Number : 5381981 **Diagnostician** : Wes Davis
Test Package : MOB 2

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com
 T:
 F: (709)737-2926

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.