




# PROBLEM SUMMARY


Area  
**CARIBOU FALLS GS**  
 Machine Id  
**FP4G1**  
 Component  
**Turbine Bearing**  
 Fluid  
**ESSO TERESSO ISO 46 (--- GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ 38555	▲ 25905	▲ 27434
Particles >6µm	ASTM D7647	>2500	▲ 2906	▲ 3302	▲ 3282
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 22/19/12	▲ 22/19/13	▲ 22/19/12

Customer Id: ONTKEE  
 Sample No.: WC0686291  
 Lab Number: 02499210  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	May 24 2023	?	We recommend you service the filters on this component.
Resample	MISSED	May 24 2023	?	We recommend an early resample to monitor this condition.
Information Required	MISSED	May 24 2023	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## HISTORICAL DIAGNOSIS

### 13 Apr 2021 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 28 May 2020 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Component wear rates appear to be normal (unconfirmed). Particles >4µm are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 25 Mar 2019 Diag: Kevin Marson

DIRT



Check seals and/or filters for points of contaminant entry. Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**CARIBOU FALLS GS**  
 Machine Id  
**FP4G1**  
 Component  
**Turbine Bearing**  
 Fluid  
**ESSO TERESSO ISO 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0686291</b>	WC0560609	WC0475094
Sample Date	Client Info		<b>11 Jul 2022</b>	13 Apr 2021	28 May 2020
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<b>2</b>	2	<1
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Aluminum	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m)	>20	<b>2</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m)	>20	<b>7</b>	<1	0
Antimony	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<b>0</b>	<1	0
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m)	0	<b>0</b>	<1	0
Phosphorus	ppm	ASTM D5185(m)	2.4	<b>&lt;1</b>	<1	0
Zinc	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	<1	<1
Sulfur	ppm	ASTM D5185(m)		<b>1969</b>	2049	2036
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1


## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185(m)		<b>0</b>	<1	0
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	1


## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 38555</b>	▲ 25905	▲ 27434
Particles >6µm	ASTM D7647	>2500	<b>▲ 2906</b>	▲ 3302	▲ 3282
Particles >14µm	ASTM D7647	>160	<b>29</b>	63	33
Particles >21µm	ASTM D7647	>40	<b>4</b>	14	6
Particles >38µm	ASTM D7647	>10	<b>0</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	<b>▲ 22/19/12</b>	▲ 22/19/13	▲ 22/19/12


### Particle Trend




### Particle Trend



### Acid Number



### Viscosity @ 40°C




### FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D974* 0.02	<b>0.12</b>	0.08	0.10
VISUAL				
method	limit/base	current	history1	history2
White Metal	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Silt	scalar Visual* NONE	<b>VLITE</b>	NONE	NONE
Debris	scalar Visual* NONE	<b>NONE</b>	LIGHT	NONE
Sand/Dirt	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar Visual* NORML	<b>NORML</b>	NORML	NORML
Odor	scalar Visual* NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar Visual* >2	<b>NEG</b>	NEG	NEG
Free Water	scalar Visual*	<b>NEG</b>	NEG	NEG

### FLUID PROPERTIES


method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D7279(m) 46	<b>46.3</b>	43.7	48.7

### SAMPLE IMAGES




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### Particle Count



#### Acid Number



ISO 17025:2017  
Accredited  
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
 Sample No. : WC0686291  
 Lab Number : 02499210  
 Unique Number : 5424170  
 Test Package : IND 2 ( Additional Tests: PrtCount, TAN Man )

**Ontario Power Generation**  
 KENORA PRODUCTION CENTRE, 200-60 FOURTEENTH ST. N.  
 KENORA, ON  
 CA P9N 4M9  
 Contact: Josh Robinson  
 josh.robinson@opg.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.