




PROBLEM SUMMARY

Area
EAR FALLS GS
 Machine Id
FP1G3
 Component
Thrust Bearing
 Fluid
ESSO TERESSO ISO 46 (--- GAL)

Sample Rating Trend



VISUAL METAL



COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

Resample at the next service interval to monitor.
 NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ATTENTION | NORMAL | ATTENTION |
|---------------|--------|---------|------|-----------|--------|-----------|
| White Metal | scalar | Visual* | NONE | ▲ VLITE | NONE | NONE |
| PrtFilter | | | | | | |

Customer Id: ONTKEE
 Sample No.: WC0686268
 Lab Number: 02499223
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|----------------------|--------|-------------|---------|--|
| Information Required | MISSED | May 24 2023 | ? | NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. |

HISTORICAL DIAGNOSIS

03 May 2021 Diag: Kevin Marson

NORMAL



Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) R&O OIL ISO 46. Please confirm. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



31 Aug 2020 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Component wear rates appear to be normal (unconfirmed). There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



07 Jul 2020 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

VISUAL METAL

Area
EAR FALLS GS
 Machine Id
FP1G3
 Component
Thrust Bearing
 Fluid
ESSO TERESSO ISO 46 (--- GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.
 NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

Light concentration of visible metal present.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0686268 | WC0560624 | WC |
| Sample Date | Client Info | | 25 Mar 2022 | 03 May 2021 | 31 Aug 2020 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ATTENTION | NORMAL | ATTENTION |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >2 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-------------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185(m) >85 | <1 | <1 | <1 |
| Chromium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | <1 | 0 | <1 |
| Titanium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) | 0 | <1 | <1 |
| Aluminum | ppm | ASTM D5185(m) >40 | <1 | <1 | <1 |
| Lead | ppm | ASTM D5185(m) >60 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185(m) >7 | 0 | <1 | <1 |
| Tin | ppm | ASTM D5185(m) >40 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185(m) | 0 | 0 | <1 |
| Vanadium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185(m) 0 | <1 | <1 | <1 |
| Barium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) 0 | 0 | <1 | <1 |
| Calcium | ppm | ASTM D5185(m) 0 | 0 | <1 | <1 |
| Phosphorus | ppm | ASTM D5185(m) 2.4 | 1 | 1 | <1 |
| Zinc | ppm | ASTM D5185(m) 0 | <1 | <1 | 1 |
| Sulfur | ppm | ASTM D5185(m) | 1895 | 1898 | 1905 |
| Lithium | ppm | ASTM D5185(m) | <1 | <1 | <1 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185(m) >20 | <1 | 1 | <1 |
| Sodium | ppm | ASTM D5185(m) | 0 | <1 | 0 |
| Potassium | ppm | ASTM D5185(m) >20 | 0 | <1 | 0 |

FLUID CLEANLINESS





| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|----------------|----------|------------|
| Particles >4µm | ASTM D7647 | >10000 | 337 | 525 | ▲ 16227 |
| Particles >6µm | ASTM D7647 | >2500 | 27 | 150 | 1295 |
| Particles >14µm | ASTM D7647 | >160 | 2 | 13 | 67 |
| Particles >21µm | ASTM D7647 | >40 | 1 | 5 | 18 |
| Particles >38µm | ASTM D7647 | >10 | 1 | 0 | 0 |
| Particles >71µm | ASTM D7647 | >3 | 1 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/18/14 | 16/12/9 | 16/14/11 | ▲ 21/17/13 |

Particle Filter (Magn: 200 x)





OIL ANALYSIS REPORT




| FLUID DEGRADATION | method | limit/base | current | history1 | history2 | |
|-------------------|----------|------------|---------|-------------|----------|------|
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.02 | 0.11 | 0.05 | 0.10 |

| VISUAL | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|----------------|----------|-------|
| White Metal | scalar | Visual* | NONE | ▲ VLITE | NONE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Debris | scalar | Visual* | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | >2 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 | |
|------------------|--------|---------------|---------|-------------|----------|------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 46 | 44.4 | 44.0 | 44.0 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0686268 **Received** : 12 Jul 2022
Lab Number : **02499223** **Diagnosed** : 14 Jul 2022
Unique Number : 5424183 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: BottomAnalysis, FilterPatch, PrtCount, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Ontario Power Generation
 KENORA PRODUCTION CENTRE, 200-60 FOURTEENTH ST. N.
 KENORA, ON CA P9N 4M9
 Contact: Josh Robinson
 josh.robinson@opg.com
 T:
 F: