




FUEL REPORT

Sample Rating Trend



ISO



Area
GARNISON DE MTL [VQ6028]
 Machine Id
CATERPILLAR GD12162
 Component
Diesel Fuel
 Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- LTR)

DIAGNOSIS

Recommendation

Les tests de laboratoire indiquent que ce carburant peut être utilisé et qu'il répond à toutes les exigences. Nous avons pris note que la vidange d'huile a été effectuée au moment de l'échantillonnage. Nous vous recommandons de filtrer ce fluide avant de l'utiliser. Nous vous recommandons d'échantillonner de nouveau dès que possible afin de contrôler la situation.

Contaminants

Il y a une quantité modérée de particules (de 4 à 38 microns) dans le carburant. La teneur en eau est négligeable.

Fuel Condition

le carburant peut encore servir si la contamination peut être réduite à un niveau acceptable.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	GD0005219	GD0004436	---
Sample Date	Client Info	20 Jul 2022	29 Sep 2020	---
Machine Age	mths	Client Info	595	544
Sample Status			ABNORMAL	NORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Specific Gravity	ASTM D1298*	0.839	0.817	0.822
Fuel Color	text	Visual Screen*	Yellow	Pink
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	1.9
Pensky-Martens Flash Point	°C	ASTM D7215*	52	47

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	15

DISTILLATION

method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	153
5% Distillation Point	°C	ASTM D2887*		168
10% Distill Point	°C	ASTM D2887*	201	174
15% Distillation Point	°C	ASTM D2887*		182
20% Distill Point	°C	ASTM D2887*	216	189
30% Distill Point	°C	ASTM D2887*	230	205
40% Distill Point	°C	ASTM D2887*	243	220
50% Distill Point	°C	ASTM D2887*	255	236
60% Distill Point	°C	ASTM D2887*	267	252
70% Distill Point	°C	ASTM D2887*	280	266
80% Distill Point	°C	ASTM D2887*	295	280
85% Distillation Point	°C	ASTM D2887*		290
90% Distill Point	°C	ASTM D2887*	310	304
95% Distillation Point	°C	ASTM D2887*		326
Final Boiling Point	°C	ASTM D2887*	341	344

IGNITION QUALITY

method	limit/base	current	history1	history2
API Gravity	ASTM D1298*	37.7	41	40
Cetane Index	ASTM D4737*	<40.0	50	51

CONTAMINANTS






method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0
Sodium	ppm	ASTM D5185(m)	<0.1	0
Potassium	ppm	ASTM D5185(m)	<0.1	0
Water	%	ASTM D6304*	<0.05	0.003
ppm Water	ppm	ASTM D6304*	<500	39.8

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 9113	949
Particles >6µm	ASTM D7647	>640	▲ 2093	221
Particles >14µm	ASTM D7647	>80	▲ 200	15
Particles >21µm	ASTM D7647	>20	▲ 54	4
Particles >38µm	ASTM D7647	>4	3	0
Particles >71µm	ASTM D7647	>3	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/18/15	17/15/11






FUEL REPORT



HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	---
Nickel	ppm	ASTM D5185(m)	<0.1	0	---
Lead	ppm	ASTM D5185(m)	<0.1	<1	---
Vanadium	ppm	ASTM D5185(m)	<0.1	0	---
Iron	ppm	ASTM D5185(m)	<0.1	<1	---
Calcium	ppm	ASTM D5185(m)	<0.1	<1	---
Magnesium	ppm	ASTM D5185(m)	<0.1	0	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	---
Zinc	ppm	ASTM D5185(m)	<0.1	<1	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					no image
Bottom					no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : GD0005219
Lab Number : 02502397
Unique Number : 5435358
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

Received : 28 Jul 2022
Tested : 02 Aug 2022
Diagnosed : 02 Aug 2022 - Kevin Marson
Generatrice Drummond
 243 rue des ARTISANS
 SAINT-GERMAIN-DE-GRANTHAM, QC
 CA J0C 1K0
 Contact: Valerie Poirier
 poiirivalerie@generatricedrummond.com
 T: (819)398-6811
 F: (819)398-7022

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.