




PROBLEM SUMMARY

Sample Rating Trend



WEAR



Area

8

Machine Id

8-2-301-B FM #2 Trunion - Feed End

Component


Journal Bearing

Fluid


MOBIL MOBILGEAR SHC 460 (350 LTR)

COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Non-ferrous Metals



RECOMMENDATION

We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	NORMAL
Tin	ppm	ASTM D5185(m)	>80	▲ 160	23	55
Antimony	ppm	ASTM D5185(m)		▲ 14	3	7
Visc @ 40°C	cSt	ASTM D7279(m)	477	▲ 413	411	453

Customer Id: STMBOW
 Sample No.: WC0714975
 Lab Number: 02507465
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	MISSED	Dec 07 2022	?	We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).

HISTORICAL DIAGNOSIS

16 May 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



11 Jan 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



17 Nov 2021 Diag: Bill Quesnel

WEAR



We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Aluminum and tin ppm levels are severe. Antimony ppm levels are noted. Iron ppm levels are marginal. Bearing wear is indicated. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Calcium and/or magnesium levels higher than normal indicating possible contamination with cement dust, advise investigate. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area

8

Machine Id

8-2-301-B FM #2 Trunion - Feed End

Component

Journal Bearing

Fluid

MOBIL MOBILGEAR SHC 460 (350 LTR)

DIAGNOSIS

Recommendation

We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).

Wear

Tin and antimony ppm levels are abnormal. A sharp increase in the tin level is noted. A sharp increase in the antimony level is noted. Bearing wear is indicated.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0714975	WC0685797	WC0655809
Sample Date	Client Info		26 Jul 2022	16 May 2022	11 Jan 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>60	10	5	7
Chromium	ppm	ASTM D5185(m)		0	0	0
Nickel	ppm	ASTM D5185(m)		<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>4	1	<1	2
Lead	ppm	ASTM D5185(m)	>250	9	1	3
Copper	ppm	ASTM D5185(m)	>125	5	2	4
Tin	ppm	ASTM D5185(m)	>80	▲ 160	23	55
Antimony	ppm	ASTM D5185(m)		▲ 14	3	7
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	5.7	1	2	24
Barium	ppm	ASTM D5185(m)	0.0	0	0	<1
Molybdenum	ppm	ASTM D5185(m)	0.0	0	0	0
Manganese	ppm	ASTM D5185(m)	0.0	<1	0	0
Magnesium	ppm	ASTM D5185(m)	0.0	2	<1	1
Calcium	ppm	ASTM D5185(m)	0.0	59	9	26
Phosphorus	ppm	ASTM D5185(m)	180	265	330	401
Zinc	ppm	ASTM D5185(m)	0.8	<1	1	2
Sulfur	ppm	ASTM D5185(m)	4270	1378	1356	4465
Lithium	ppm	ASTM D5185(m)		<1	0	0

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>50	4	4	6
Sodium	ppm	ASTM D5185(m)		<1	0	<1
Potassium	ppm	ASTM D5185(m)	>20	2	2	3


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		179234	185921	324383
Particles >6µm	ASTM D7647	>320000	148857	120081	206375
Particles >14µm	ASTM D7647	>160000	34409	13380	8906
Particles >21µm	ASTM D7647	>40000	4865	2008	239
Particles >38µm	ASTM D7647	>10000	38	28	0
Particles >71µm	ASTM D7647	>2500	0	8	0
Oil Cleanliness	ISO 4406 (c)	>--/25/24	25/24/22	25/24/21	26/25/20


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.38	0.56	0.91	0.81

Particle Trend



Non-ferrous Metals





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	477 ▲ 413	411	453

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals







Viscosity @ 40°C



Particle Count



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0714975 **Received** : 26 Aug 2022
Lab Number : 02507465 **Diagnosed** : 29 Aug 2022
Unique Number : 5448435 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

ST. MARYS CEMENT CO.
 400 BOWMANVILLE AVENUE
 BOWMANVILLE, ON
 CA L1C 7B5
 Contact: Lou Traiforos
 lou.traiforos@vcimentos.com
 T: (905)440-5874
 F: (905)623-4695