




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
GFW DIESEL (S/N I060967959)

Component
Diesel Engine

Fluid
DIESEL ENGINE OIL SAE 40 (27 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0445152	WC0445231	WC985088
Sample Date	Client Info			19 Oct 2022	03 Apr 2022	18 Jun 2020
Machine Age	hrs	Client Info		0	0	261
Oil Age	hrs	Client Info		0	0	261
Oil Changed	Client Info			N/A	N/A	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method		>3.0	<1.0	<1.0	<1.0
Glycol	WC Method			NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>90	6	6	7
Chromium	ppm	ASTM D5185(m)	>20	0	<1	<1
Nickel	ppm	ASTM D5185(m)	>2	0	<1	<1
Titanium	ppm	ASTM D5185(m)	>2	<1	0	<1
Silver	ppm	ASTM D5185(m)	>2	1	1	1
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>40	2	2	1
Copper	ppm	ASTM D5185(m)	>330	6	5	4
Tin	ppm	ASTM D5185(m)	>15	<1	<1	<1
Antimony	ppm	ASTM D5185(m)		<1	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0



ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	250	1	2	2
Barium	ppm	ASTM D5185(m)	10	0	0	<1
Molybdenum	ppm	ASTM D5185(m)	100	44	43	46
Manganese	ppm	ASTM D5185(m)		<1	<1	<1
Magnesium	ppm	ASTM D5185(m)	450	818	835	864
Calcium	ppm	ASTM D5185(m)	3000	1275	1187	1300
Phosphorus	ppm	ASTM D5185(m)	1150	1086	1053	1103
Zinc	ppm	ASTM D5185(m)	1350	1242	1206	1317
Sulfur	ppm	ASTM D5185(m)	4250	3031	2913	3154
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	5	5	5
Sodium	ppm	ASTM D5185(m)	>216	5	4	3
Potassium	ppm	ASTM D5185(m)	>20	1	1	2

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>6	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	7.3	6.8	8.0
Sulfation	Abs/.1mm	ASTM D7415*	>30	19.7	19.9	22.4



OIL ANALYSIS REPORT











FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	ASTM D7414*	>25	16.1	15.3	13.4
Base Number (BN)	mg KOH/g	ASTM D2896*	8.5	7.78	7.92	---

VISUAL	method	limit/base	current	history1	history2	
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	12.9	13.1	12.8

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0445152 **Received** : 20 Oct 2022
Lab Number : **02517452** **Diagnosed** : 21 Oct 2022
Unique Number : 5474432 **Diagnostician** : Kevin Marson
Test Package : MOB 2

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com
 T:
 F: (709)737-2926

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.