

# **PROBLEM SUMMARY**

# Sample Rating Trend


ISO



Component **Governor System** 

ESSO TERESSO ISO 68 (727 LTR)

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ATTENTION	ABNORMAL	ABNORMAL			
Particles >4μm	ASTM D7647	>20000	<b>△</b> 36929	<u>▲</u> 58541	<u>▲</u> 80380			
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<u>22/19/13</u>	23/20/14	<u>4</u> 24/21/15			

<u>, lalalana i alalana i anno allalanti (IIII</u>

Customer Id: NEWSTJ Sample No.: WC0445362 Lab Number: 02517587 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

## **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter	MISSED	Dec 20 2022	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS

28 Oct 2021 Diag: Wes Davis



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles  $>4\mu m$  are abnormally high. Particles  $>6\mu m$  are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 06 Apr 2021 Diag: Wes Davis





We recommend you service the filters on this component. We recommend an early resample to monitor this condition.All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 20 Oct 2020 Diag: Wes Davis

150



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles  $>4\mu m$  are abnormally high. Particles  $>6\mu m$  are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Area [192028] TCV -G1-GOV

**Governor System** 

ESSO TERESSO ISO 68 (727 LTR)

# Sample Rating Trend



## **DIAGNOSIS**

## Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

## Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		ir2004 Mar200		Dec2012 Apr2015 Nov2017	Apr2020	
SAMPLE INFORMA	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0445362	WC0445204	WC0316796
Sample Date		Client Info		01 Jun 2022	28 Oct 2021	06 Apr 2021
Machine Age	nrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron p	opm	ASTM D5185(m)	>50	2	2	3
Chromium p	opm	ASTM D5185(m)		0	0	0
Nickel p	opm	ASTM D5185(m)		0	<1	0
Titanium p	opm	ASTM D5185(m)		0	0	0
Silver	opm	ASTM D5185(m)		0	<1	0
Aluminum p	opm	ASTM D5185(m)	>3	0	<1	<1
Lead	opm	ASTM D5185(m)	>75	1	2	2
Copper	opm	ASTM D5185(m)	>15	1	2	2
Tin p	opm	ASTM D5185(m)	>55	1	1	1
Antimony p	opm	ASTM D5185(m)		<1	<1	<1
Vanadium	opm	ASTM D5185(m)		0	0	0
Beryllium p	opm	ASTM D5185(m)		0	0	0
Cadmium p	opm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron p	opm	ASTM D5185(m)	4.5	0	<1	<1
Barium p	opm	ASTM D5185(m)	0.4	0	0	0
Molybdenum p	opm	ASTM D5185(m)	0	0	0	<1
Manganese p	opm	ASTM D5185(m)		0	0	0
Magnesium p	opm	ASTM D5185(m)	0	<1	<1	<1
Calcium	opm	ASTM D5185(m)	0	4	5	6
Phosphorus p	opm	ASTM D5185(m)	0.7	4	5	5
Zinc	opm	ASTM D5185(m)	0	3	4	4
Sulfur p	opm	ASTM D5185(m)	1315	1458	1418	1421
Lithium p	opm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	opm	ASTM D5185(m)	>8	<1	<1	<1
Sodium	opm	ASTM D5185(m)		1	1	2
Potassium p	opm	ASTM D5185(m)	>20	<1	<1	<1
FLUID CLEANLINE	SS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	<b>▲</b> 36929	▲ 58541	▲ 80380
Particles >6µm		ASTM D7647	>5000	4230	<u>▲</u> 7293	▲ 15265
Particles >14µm		ASTM D7647	>640	71	106	319
Particles >21µm		ASTM D7647	>160	16	18	60
Particles >38µm		ASTM D7647	>40	1	0	4
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<b>22/19/13</b>	<u>△</u> 23/20/14	<u>4</u> 24/21/15
FLUID DEGRADAT	ION	method	limit/base	current	history1	history2

Acid Number (AN)


mg KOH/g ASTM D974\* 0.02


0.11


0.12



# **OIL ANALYSIS REPORT**









CALA ISO 17025:2017 Accredited

Laboratory

Laboratory Sample No. Lab Number **Unique Number** 

: WC0445362

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : 02517587

Received Diagnosed

: 21 Oct 2022 Diagnostician : Wes Davis

: 20 Oct 2022

: 5474567 Test Package : IND 2 (Additional Tests: TAN Man) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**NEWFOUNDLAND POWER INC.** 

50 DUFFY PLACE, PO BOX 8910 ST. JOHNS, NL CA A1B 3P6

Contact: Paul Martin pmartin@newfoundlandpower.com

F: (709)737-2926

T: