PROBLEM SUMMARY

Sample Rating Trend



ISO

Machine Id
SCV G2 THBR
Component
Thrust Bearing
Fluid
MOBIL DTE OIL HVY MEDIUM (24 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				**SEVERE**	SEVERE	ABNORMAL
Particles >4µm		ASTM D7647	>10000	**241731**	81520	71038
Particles >6µm		ASTM D7647	>2500	**187678**	13409	10401
Particles >14µm		ASTM D7647	>160	**18758**	848	943
Particles >21µm		ASTM D7647	>40	**863**	200	273
Oil Cleanliness		ISO 4406 (c)	>20/18/14	**25/25/21**	24/21/17	23/21/17
White Metal	scalar	Visual*	NONE	**LIGHT**	NONE	NONE
PrtFilter						

Customer Id: NEWSTJ
Sample No.: WC0445192
Lab Number: 02517618
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Dec 20 2022	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	MISSED	Dec 20 2022	?	Resample in 30-45 days to monitor this situation.
Check Breathers	MISSED	Dec 20 2022	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	MISSED	Dec 20 2022	?	We advise that you check all areas where contaminants can enter the system.
Check For Visual Metal	MISSED	Dec 20 2022	?	We advise that you check for visible metal particles in the oil.
Filter Fluid	MISSED	Dec 20 2022	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

03 Feb 2022 Diag: Kevin Marson

ISO

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.All component wear rates are normal. Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

04 May 2021 Diag: Kevin Marson

ISO

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.All component wear rates are normal. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >38µm are abnormally high. Particles >6µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

26 Nov 2020 Diag: Kevin Marson

ISO

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.Light concentration of visible metal present. Particles >21µm are severely high. Particles >4µm are abnormally high. Particles >38µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
SCV G2 THBR
Component
Thrust Bearing
Fluid
MOBIL DTE OIL HVY MEDIUM (24 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear

Moderate concentration of visible metal present. Bearing wear is indicated.

Contamination

Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

Particle Filter (Magn: 100 x)



SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0445192**	WC0328012	WC0328006
Sample Date		Client Info		**01 May 2022**	03 Feb 2022	04 May 2021
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**SEVERE**	SEVERE	ABNORMAL

CONTAMINATION	method	limit/base	current	history1	history2
Water	WC Method	>2	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>85	**35**	4	4
Chromium	ppm	ASTM D5185(m)		**0**	0	0
Nickel	ppm	ASTM D5185(m)		**0**	<1	<1
Titanium	ppm	ASTM D5185(m)		**0**	0	0
Silver	ppm	ASTM D5185(m)		**0**	0	0
Aluminum	ppm	ASTM D5185(m)	>40	**0**	0	0
Lead	ppm	ASTM D5185(m)	>60	**<1**	1	1
Copper	ppm	ASTM D5185(m)	>7	**1**	<1	<1
Tin	ppm	ASTM D5185(m)	>40	**16**	29	27
Antimony	ppm	ASTM D5185(m)		**2**	2	2
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		**0**	<1	<1
Barium	ppm	ASTM D5185(m)		**0**	0	0
Molybdenum	ppm	ASTM D5185(m)		**0**	0	0
Manganese	ppm	ASTM D5185(m)		**<1**	0	0
Magnesium	ppm	ASTM D5185(m)		**<1**	0	0
Calcium	ppm	ASTM D5185(m)		**0**	0	<1
Phosphorus	ppm	ASTM D5185(m)		**12**	3	3
Zinc	ppm	ASTM D5185(m)		**4**	2	2
Sulfur	ppm	ASTM D5185(m)		**117**	140	143
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>20	**<1**	<1	<1
Sodium	ppm	ASTM D5185(m)		**<1**	0	0
Potassium	ppm	ASTM D5185(m)	>20	**<1**	<1	<1

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	**241731**	81520	71038
Particles >6µm	ASTM D7647	>2500	**187678**	13409	10401
Particles >14µm	ASTM D7647	>160	**18758**	848	943
Particles >21µm	ASTM D7647	>40	**863**	200	273
Particles >38µm	ASTM D7647	>10	**12**	10	21
Particles >71µm	ASTM D7647	>3	**1**	1	3
Oil Cleanliness	ISO 4406 (c)	>20/18/14	**25/25/21**	24/21/17	23/21/17

OIL ANALYSIS REPORT

Particle Count



Particle Trend



Acid Number



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		**0.08**	0.11	0.11

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	▲ **LIGHT**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	VLITE
Silt	scalar	Visual*	NONE	**LIGHT**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>2	**NEG**	.2%	.2%
Free Water	scalar	Visual*		**NEG**	NEG	.2%

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	65.1	**65.5**	66.5	66.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					
PrtFilter					



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0445192 **Received** : 20 Oct 2022
Lab Number : 02517618 **Diagnosed** : 24 Oct 2022
Unique Number : 5474598 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: BottomAnalysis, FilterPatch, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

NEWFOUNDLAND POWER INC.
50 DUFFY PLACE, PO BOX 8910
ST. JOHNS, NL
CA A1B 3P6
Contact: Paul Martin
pmartin@newfoundlandpower.com
T:
F: (709)737-2926