




# PROBLEM SUMMARY

Sample Rating Trend




Area  
**[192031]**  
 Machine Id  
**PBK G LGBR**

Component  
**Bearing**  
 Fluid  
**MOBIL DTE OIL HVY MEDIUM (136 LTR)**

## COMPONENT CONDITION SUMMARY

### Non-ferrous Metals



## RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend that you change the oil. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	ABNORMAL
Copper	ppm	ASTM D5185(m)	>13	SEVERE 33	SEVERE 29	ABNORMAL 1
Precipitate	scalar	Visual*	NONE	LIGHT	NONE	NONE
Appearance	scalar	Visual*	NORML	MILKY	NORML	NORML
Free Water	scalar	Visual*		5%	1%	NEG

Customer Id: NEWSTJ  
 Sample No.: WC0445369  
 Lab Number: 02517641  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	MISSED	Dec 21 2022	?	We recommend that you change the oil.
Resample	MISSED	Dec 21 2022	?	We recommend an early resample to monitor this condition.
Check Breathers	MISSED	Dec 21 2022	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access	MISSED	Dec 21 2022	?	We advise that you check for the source of water entry.
Check Seals	MISSED	Dec 21 2022	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	MISSED	Dec 21 2022	?	We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil.

## HISTORICAL DIAGNOSIS

### 20 Oct 2021 Diag: Kevin Marson

#### WEAR



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We recommend that you drain the oil from the component if this has not already been done. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. NOTE: Test values may be askew due high concentration of free water present in sample. Copper ppm levels are severe. Lead ppm levels are noted. A sharp increase in the lead level is noted. A sharp increase in the copper level is noted. Bearing wear is indicated. Free water present. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



### 30 Apr 2021 Diag: Kevin Marson

#### ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 15 Oct 2020 Diag: Kevin Marson

#### ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of laboratory tests is based on sample, as received from client. Source of sample and sampling technique cannot be verified. All component wear rates are normal. Particles >71µm are severely high. Particles >14µm are severely high. Particles >21µm are severely high. Particles >38µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. Moderate concentration of visible dirt/debris present in the oil. The water content is negligible. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



Area  
**[192031]**  
 Machine Id  
**PBK G LGBR**  
 Component  
**Bearing**  
 Fluid  
**MOBIL DTE OIL HVY MEDIUM (136 LTR)**

## DIAGNOSIS

**Recommendation**  
 We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend that you change the oil. We recommend an early resample to monitor this condition.

**Wear**  
 Copper ppm levels are severe. Bearing wear is indicated.

**Contamination**  
 There is a moderate concentration of water present in the oil. Free water present.

**Fluid Condition**  
 The white residue present in the sample is oil additive precipitate. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0445369</b>	WC0445207	WC0327923
Sample Date	Client Info	<b>02 Jun 2022</b>	20 Oct 2021	30 Apr 2021
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	<b>0</b>	0	0	
Iron	ppm	ASTM D5185(m) >63	<b>19</b>	21	29
Chromium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185(m) >2	<b>0</b>	0	0
Lead	ppm	ASTM D5185(m) >161	<b>21</b>	78	6
Copper	ppm	ASTM D5185(m) >13	<b>33</b>	29	1
Tin	ppm	ASTM D5185(m) >27	<b>2</b>	3	2
Antimony	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>&lt;1</b>	1	<1

## ADDITIVES






method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Barium	ppm	ASTM D5185(m)	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	<b>0</b>	0	<1
Calcium	ppm	ASTM D5185(m)	<b>&lt;1</b>	1	<1
Phosphorus	ppm	ASTM D5185(m)	<b>131</b>	131	3
Zinc	ppm	ASTM D5185(m)	<b>17</b>	24	13
Sulfur	ppm	ASTM D5185(m)	<b>800</b>	774	2341
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >12	<b>&lt;1</b>	1	<1
Sodium	ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	<1
Water	%	ASTM D6304* >2	<b>0.164</b>	0.181	0.003
ppm Water	ppm	ASTM D6304*	<b>1644.5</b>	1811.1	35.5

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.02</b>	0.07	0.14



ISO 17025:2017  
Accredited  
Laboratory


**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0445369  
**Lab Number** : 02517641  
**Unique Number** : 5474621  
**Test Package** : IND 2 ( Additional Tests: Bottom, KF )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	▲ LIGHT	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	VLITE
Appearance	scalar	Visual*	▲ MILKY	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	.5%	1%
Free Water	scalar	Visual*		▲ 5%	▲ 1%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	65.1	69.3	68.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**NEWFOUNDLAND POWER INC.**  
 50 DUFFY PLACE, PO BOX 8910  
 ST. JOHNS, NL  
 CA A1B 3P6  
 Contact: Paul Martin  
 pmartin@newfoundlandpower.com  
 T:  
 F: (709)737-2926