



PROBLEM SUMMARY

Area
Shipping [2881625]
 Machine Id
GAULIN HOMOGENIZER
 Component
Circulating Oil
 Fluid
SWEPCO 757 ISO 220 (10 GAL)

Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY

Viscosity @ 40°C



RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	---	---
Free Water	scalar	Visual*	▲ 5%	---	---

Customer Id: HEXEDM
 Sample No.: WC0525790
 Lab Number: 02520345
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access	---	---	?	We advise that you check for the source of water entry.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.


HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Area
Shipping [2881625]
 Machine Id
GAULIN HOMOGENIZER
 Component
Circulating Oil
 Fluid
SWEPCO 757 ISO 220 (10 GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate concentration of water present in the oil. Free water present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code.

Fluid Condition

The viscosity of the oil is higher than normal, possibly indicating the addition of a heavier grade of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0525790	---	---
Sample Date	Client Info		19 Oct 2022	---	---
Machine Age	Client Info		0	---	---
Oil Age	Client Info		1	---	---
Oil Changed	Client Info		Changed	---	---
Sample Status			ABNORMAL	---	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m)	>20	<1	---	---
Chromium	ppm ASTM D5185(m)	>20	0	---	---
Nickel	ppm ASTM D5185(m)	>20	0	---	---
Titanium	ppm ASTM D5185(m)		0	---	---
Silver	ppm ASTM D5185(m)		0	---	---
Aluminum	ppm ASTM D5185(m)	>20	<1	---	---
Lead	ppm ASTM D5185(m)	>20	0	---	---
Copper	ppm ASTM D5185(m)	>20	<1	---	---
Tin	ppm ASTM D5185(m)	>20	0	---	---
Antimony	ppm ASTM D5185(m)		0	---	---
Vanadium	ppm ASTM D5185(m)		0	---	---
Beryllium	ppm ASTM D5185(m)		0	---	---
Cadmium	ppm ASTM D5185(m)		0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)		1	---	---
Barium	ppm ASTM D5185(m)		0	---	---
Molybdenum	ppm ASTM D5185(m)		0	---	---
Manganese	ppm ASTM D5185(m)		0	---	---
Magnesium	ppm ASTM D5185(m)		<1	---	---
Calcium	ppm ASTM D5185(m)		1	---	---
Phosphorus	ppm ASTM D5185(m)		9	---	---
Zinc	ppm ASTM D5185(m)		<1	---	---
Sulfur	ppm ASTM D5185(m)		2914	---	---
Lithium	ppm ASTM D5185(m)		<1	---	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m)	>15	<1	---	---
Sodium	ppm ASTM D5185(m)		<1	---	---
Potassium	ppm ASTM D5185(m)	>20	0	---	---

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	4043	---	---
Particles >6µm	ASTM D7647	>1300	987	---	---
Particles >14µm	ASTM D7647	>160	75	---	---
Particles >21µm	ASTM D7647	>40	22	---	---
Particles >38µm	ASTM D7647	>10	2	---	---
Particles >71µm	ASTM D7647	>3	2	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	19/17/13	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*		0.06	---	---



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---
Emulsified Water	scalar	Visual*		.5%	---	---
Free Water	scalar	Visual*		▲ 5%	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	212.9	265	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Hexion Canada Inc. - EDMONTON PLANT
Sample No. : WC0525790 **Received** : 02 Nov 2022 12621 - 156th Street NW
Lab Number : 02520345 **Diagnosed** : 03 Nov 2022 Edmonton, AB
Unique Number : 5477325 **Diagnostician** : Kevin Marson CA T5V 1E1
Test Package : IND 2 (Additional Tests: PrtCount, TAN Man) Contact: Scott Mckenzie
scott.mckenzie@henxion.com
T: (780)447-8469
F: (780)447-7268

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.