

PROBLEM SUMMARY

Sample Rating Trend

COMBUSTION




CHAUDIERE GS5 [45292] PROLEC GE TN11605-T4C22 (S/N M16E15909)

Main Transformer Oil

ENVIROTEMP FR3 FLUID (1808 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE				
DGA - CO2	ppm	ASTM D3612(e)*		△ 6607				
DGA - Ethane	ppm	ASTM D3612(e)*		1067				
DGA - Total Combustible Gas	ppm	ASTM D3612(e)*		<u> </u>				
Acid Number (AN)	mg KOH/g	ASTM D974*	0.22	0.11				

Customer Id: ENE271OTT **Sample No.:** WC0592374 Lab Number: 02531370 Test Package: TRF 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Bill Quesnel CLS, OMA II, MLA-III, LLA-I +1 (289)291-4641 x4641

Bill.Quesnel@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Resample			?	We recommend an early resample to monitor this condition.			
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.			

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend

COMBUSTION



CHAUDIERE GS5 [45292] PROLEC GE TN11605-T4C22 (S/N M16E15909)

Main Transformer Oil

ENVIROTEMP FR3 FLUID (1808 GAL)

DIAGNOSIS Recommendation

We recommend an early resample to monitor this condition.

Contamination

Ethane level exceeded (>65, 0.0065%) indicating low energy arcing in a confined space. Carbon Dioxide levels exceeded (>2500, 0.25%). General conductor overheating indicated.

▲ Fluid Condition

The AN level is at the top-end of the recommended


CAMPLE	. A TION			Dec2022			
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0592374			
Sample Date		Client Info		15 Dec 2022			
Machine Age	hrs	Client Info		0			
Oil Age	hrs	Client Info		0			
Oil Changed		Client Info		N/A			
Sample Status				SEVERE			
CONTAMINANTS		method	limit/base	current	history1	history2	
Water	%	ASTM D6304*	>0.02	0.008			
ppm Water	ppm	ASTM D6304*	>200	85.7			
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>5000	1607			
Particles >6µm		ASTM D7647	>1300	384			
Particles >14µm		ASTM D7647	>160	25			
Particles >21µm		ASTM D7647	>40	11			
Particles >38µm		ASTM D7647	>10	6			
Particles >71µm		ASTM D7647	>3	5			
Oil Cleanliness		ISO 4406 (c)	>19/17/14	18/16/12			
DISSOLVED GAS ANALY	YSIS (DGA)	method	limit/base	current	history1	history2	
DGA - H2	ppm	ASTM D3612(e)*		16			
DGA - O2	ppm	ASTM D3612(e)*		219			
DGA - N2	ppm	ASTM D3612(e)*		41176			
DGA - CO	ppm	ASTM D3612(e)*		55			
DGA - CO2	ppm	ASTM D3612(e)*		6607			
DGA - Methane	ppm	ASTM D3612(e)*		4			
DGA - Acetylene	ppm	ASTM D3612(e)*		0			
DGA - Ethylene	ppm	ASTM D3612(e)*		6			
DGA - Ethane	ppm	ASTM D3612(e)*		1067			
DGA - Total Gas Content	%	ASTM D3612(e)*		49150			
DGA - Total Combustible Gas	ppm	ASTM D3612(e)*		<u> </u>			
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.22	△ 0.11			
VISUAL		method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE			
Yellow Metal	scalar	Visual*	NONE	NONE			
Precipitate	scalar	Visual*	NONE	NONE			
Silt	scalar	Visual*	NONE	NONE			
Debris	scalar	Visual*	NONE	NONE			
Sand/Dirt	scalar	Visual*	NONE	NONE			
Appearance	scalar	Visual*	NORML	NORML			
Odor	scalar	Visual*	NORML	NORML			
FLUID PROPERT	IES	method	limit/base	current	history1	history2	
Specific Gravity		ASTM D4052(e)	0.92	0.920			
Dielectric Breakdown	kV	ASTM D3612(e)*		52			
ASTM Color		ACTM D1E00(a)		-1.5			

ASTM Color

scalar ASTM D1500(e)



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0592374

Lab Number : 02531370 Unique Number : 5512369

Received : 04 Jan 2023 **Tested** Diagnosed

: 04 Jan 2023 : 19 Jan 2023 - Bill Quesnel

Test Package: TRF 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Portage Power - Energy Ottawa

4 Booth Street Ottawa, ON **CA K1R 6K8**

Contact: Cheryl Gharib info@portagepower.com

T: F: x: