




# PROBLEM SUMMARY





Sample Rating Trend

DEGRADATION

Area  
**System 37 - Crude Loading**  
 Machine Id  
**G-3701A Pump / Motor Lubricating Oil**  
 Component  
**Pump**  
 Fluid  
**IRVING HYDRAULIC OIL LP 32 (1190 LTR)**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

| Sample Status    |          |                        | ABNORMAL   | SEVERE     | ABNORMAL |
|------------------|----------|------------------------|------------|------------|----------|
| Calcium          | ppm      | ASTM D5185(m)          | ▲ 0        | ▲ 3        | ▲ 9      |
| Phosphorus       | ppm      | ASTM D5185(m)          | ▲ 33       | ▲ 136      | 173      |
| Zinc             | ppm      | ASTM D5185(m) 400      | ▲ 4        | ▲ 33       | ▲ 87     |
| Particles >4µm   |          | ASTM D7647 >5000       | ▲ 15291    | ● 50289    | 4098     |
| Particles >6µm   |          | ASTM D7647 >1300       | ▲ 2680     | ▲ 4096     | 559      |
| Oil Cleanliness  |          | ISO 4406 (c) >19/17/14 | ▲ 21/19/14 | ● 23/19/15 | 19/16/12 |
| Acid Number (AN) | mg KOH/g | ASTM D974*             | ▲ 1.01     | 0.59       | 0.42     |
| Visc @ 40°C      | cSt      | ASTM D7279(m) 31.9     | ▲ 16.6     | ▲ 24.7     | ▲ 27.6   |

Customer Id: HIBSTJ  
 Sample No.: PP  
 Lab Number: 02531947  
 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

| Action             | Status | Date        | Done By | Description   |
|--------------------|--------|-------------|---------|---|
| Change Filter      | MISSED | Jan 31 2023 | ?       | We recommend you service the filters on this component.             |
| Resample           | MISSED | Jan 31 2023 | ?       | We recommend an early resample to monitor this condition.           |
| Check Fluid Source | MISSED | Jan 31 2023 | ?       | Confirm the source of the lubricant being utilized for top-up/fill. |

## HISTORICAL DIAGNOSIS

### 24 Apr 2022 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >14µm are notably high. The water content is negligible. Viscosity of sample indicates oil is within ISO 22 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 29 Dec 2021 Diag: Kevin Marson

WEAR



Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Copper ppm levels are marginal. All other component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. NOTE: The color of the oil is darker than previous samples.

view report



### 06 Oct 2021 Diag: Kevin Marson

WEAR



We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Copper ppm levels are abnormal. Lead ppm levels are noted. A sharp increase in the copper level is noted. An increase in the lead level is noted. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION

Area  
**System 37 - Crude Loading**  
 Machine Id  
**G-3701A Pump / Motor Lubricating Oil**  
 Component  
**Pump**  
 Fluid  
**IRVING HYDRAULIC OIL LP 32 (1190 LTR)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

Particles >4µm are abnormally high. Particles >6µm and oil cleanliness are abnormally high. The water content is negligible.

### Fluid Condition

The AN level is above the recommended limit. Viscosity of sample indicates oil is within ISO 15 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The oil is no longer serviceable.

## SAMPLE INFORMATION

| method        | limit/base  | current            | history1    | history2    |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | <b>PP</b>          | PP          | PP          |
| Sample Date   | Client Info | <b>05 Dec 2022</b> | 24 Apr 2022 | 29 Dec 2021 |
| Machine Age   | hrs         | <b>0</b>           | 0           | 0           |
| Oil Age       | hrs         | <b>0</b>           | 0           | 0           |
| Oil Changed   | Client Info | <b>N/A</b>         | N/A         | N/A         |
| Sample Status |             | <b>ABNORMAL</b>    | SEVERE      | ABNORMAL    |

## WEAR METALS

| method    | limit/base | current           | history1     | history2 |             |
|-----------|------------|-------------------|--------------|----------|-------------|
| Iron      | ppm        | ASTM D5185(m) >75 | <b>&lt;1</b> | <1       | 0           |
| Chromium  | ppm        | ASTM D5185(m) >5  | <b>0</b>     | 0        | 0           |
| Nickel    | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | <1          |
| Titanium  | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | 0           |
| Silver    | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | <1          |
| Aluminum  | ppm        | ASTM D5185(m) >5  | <b>0</b>     | 0        | 0           |
| Lead      | ppm        | ASTM D5185(m) >10 | <b>0</b>     | <1       | 2           |
| Copper    | ppm        | ASTM D5185(m) >15 | <b>&lt;1</b> | 25       | <b>▲ 44</b> |
| Tin       | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | <1          |
| Antimony  | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | 0           |
| Vanadium  | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | 0           |
| Beryllium | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | 0           |
| Cadmium   | ppm        | ASTM D5185(m)     | <b>0</b>     | 0        | 0           |

## ADDITIVES

| method     | limit/base | current           | history1     | history2      |             |
|------------|------------|-------------------|--------------|---------------|-------------|
| Boron      | ppm        | ASTM D5185(m)     | <b>&lt;1</b> | 2             | 1           |
| Barium     | ppm        | ASTM D5185(m)     | <b>0</b>     | 0             | 0           |
| Molybdenum | ppm        | ASTM D5185(m)     | <b>0</b>     | 0             | 0           |
| Manganese  | ppm        | ASTM D5185(m)     | <b>0</b>     | 0             | 0           |
| Magnesium  | ppm        | ASTM D5185(m)     | <b>0</b>     | 0             | <1          |
| Calcium    | ppm        | ASTM D5185(m)     | <b>▲ 0</b>   | <b>▲ 3</b>    | <b>▲ 9</b>  |
| Phosphorus | ppm        | ASTM D5185(m)     | <b>▲ 33</b>  | <b>▲ 136</b>  | <b>173</b>  |
| Zinc       | ppm        | ASTM D5185(m) 400 | <b>▲ 4</b>   | <b>▲ 33</b>   | <b>▲ 87</b> |
| Sulfur     | ppm        | ASTM D5185(m)     | <b>2647</b>  | <b>▲ 2865</b> | <b>2718</b> |
| Lithium    | ppm        | ASTM D5185(m)     | <b>&lt;1</b> | <1            | <1          |

## CONTAMINANTS


| method    | limit/base | current           | history1     | history2 |       |
|-----------|------------|-------------------|--------------|----------|-------|
| Silicon   | ppm        | ASTM D5185(m) >20 | <b>0</b>     | <1       | <1    |
| Sodium    | ppm        | ASTM D5185(m)     | <b>0</b>     | <1       | 2     |
| Potassium | ppm        | ASTM D5185(m) >20 | <b>0</b>     | 2        | 4     |
| Water     | %          | ASTM D6304*       | <b>0.009</b> | 0.004    | 0.001 |
| ppm Water | ppm        | ASTM D6304* >.1   | <b>94.9</b>  | 42.4     | 13.9  |

## FLUID CLEANLINESS


| method          | limit/base             | current           | history1          | history2 |
|-----------------|------------------------|-------------------|-------------------|----------|
| Particles >4µm  | ASTM D7647 >5000       | <b>▲ 15291</b>    | <b>● 50289</b>    | 4098     |
| Particles >6µm  | ASTM D7647 >1300       | <b>▲ 2680</b>     | <b>▲ 4096</b>     | 559      |
| Particles >14µm | ASTM D7647 >160        | <b>116</b>        | <b>▲ 168</b>      | 27       |
| Particles >21µm | ASTM D7647 >40         | <b>27</b>         | 27                | 6        |
| Particles >38µm | ASTM D7647 >10         | <b>1</b>          | 1                 | 0        |
| Particles >71µm | ASTM D7647 >3          | <b>0</b>          | 0                 | 0        |
| Oil Cleanliness | ISO 4406 (c) >19/17/14 | <b>▲ 21/19/14</b> | <b>● 23/19/15</b> | 19/16/12 |

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Additives




### ▲ Water (KF)



### ▲ Particle Trend



### ▲ Additives




| FLUID DEGRADATION |          | method     | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|---------|----------|----------|
| Acid Number (AN)  | mg KOH/g | ASTM D974* |            | ▲ 1.01  | 0.59     | 0.42     |






| VISUAL           |        | method  | limit/base | current      | history1 | history2 |
|------------------|--------|---------|------------|--------------|----------|----------|
| White Metal      | scalar | Visual* | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Yellow Metal     | scalar | Visual* | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Precipitate      | scalar | Visual* | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Silt             | scalar | Visual* | NONE       | <b>VLITE</b> | NONE     | NONE     |
| Debris           | scalar | Visual* | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Sand/Dirt        | scalar | Visual* | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Appearance       | scalar | Visual* | NORML      | <b>NORML</b> | NORML    | NORML    |
| Odor             | scalar | Visual* | NORML      | <b>NORML</b> | NORML    | NORML    |
| Emulsified Water | scalar | Visual* |            | <b>NEG</b>   | NEG      | NEG      |
| Free Water       | scalar | Visual* |            | <b>NEG</b>   | NEG      | NEG      |

| FLUID PROPERTIES |     | method        | limit/base | current | history1 | history2 |
|------------------|-----|---------------|------------|---------|----------|----------|
| Visc @ 40°C      | cSt | ASTM D7279(m) | 31.9       | ▲ 16.6  | ▲ 24.7   | ▲ 27.6   |

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **HIBERNIA MGMT & DEVELOPMENT CO. LTD**  
**Sample No.** : PP **Received** : 09 Jan 2023 **SUITE 1000,, 100 NEW GOWER STREET**  
**Lab Number** : 02531947 **Diagnosed** : 11 Jan 2023 **ST.JOHNS, NL**  
**Unique Number** : 5512946 **Diagnostician** : Kevin Marson **CA A1C 6K3**  
**Test Package** : MAR 2 ( Additional Tests: KF, TAN Man ) **Contact: Christopher Michelau**  
 christopher.j.michelau@exxonmobil.com  
 T: (709)722-3766  
 F: (709)722-3766

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.