




OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area
BRUCE A/3/43230
 Machine Id
3-43230-P3-BFP Tank Vent
 Component
Bulk Fluid Tank
 Fluid
MOBIL DTE 732 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

Phosphorus ppm levels are abnormally high. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0719041	WC	WC0696860
Sample Date	Client Info	28 Nov 2022	10 Oct 2022	05 Jul 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >10	<1	<1	<1
Chromium	ppm	ASTM D5185(m) >5	0	0	0
Nickel	ppm	ASTM D5185(m) >5	0	<1	0
Titanium	ppm	ASTM D5185(m) >5	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >5	0	0	0
Lead	ppm	ASTM D5185(m) >5	4	4	4
Copper	ppm	ASTM D5185(m) >5	0	0	<1
Tin	ppm	ASTM D5185(m) >5	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	<1	<1	0
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	<1
Calcium	ppm	ASTM D5185(m)	0	0	0
Phosphorus	ppm	ASTM D5185(m)	▲ 9	0	3
Zinc	ppm	ASTM D5185(m)	2	<1	<1
Sulfur	ppm	ASTM D5185(m)	55	54	52
Lithium	ppm	ASTM D5185(m)	<1	<1	<1


CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >5	2	2	2
Sodium	ppm	ASTM D5185(m) >5	0	0	0
Potassium	ppm	ASTM D5185(m) >20	0	<1	<1
Water	%	ASTM D6304* >0.005	0.00	0.00	0.001
ppm Water	ppm	ASTM D6304* >50	0.00	0.00	0.2


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	416	286	2924
Particles >6µm	ASTM D7647 >1300	73	54	461
Particles >14µm	ASTM D7647 >320	7	9	20
Particles >21µm	ASTM D7647 >80	2	4	6
Particles >38µm	ASTM D7647 >20	0	1	1
Particles >71µm	ASTM D7647 >4	0	1	0
Oil Cleanliness	ISO 4406 (c) >19/17/15	16/13/10	15/13/10	19/16/11


Additives




Water (KF)




Particle Trend



Water (KF)



Viscosity @ 40°C




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.10	0.06	0.07	0.07

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.005	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG


FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	30.0	31.4	31.4	31.4

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

Sample No. : WC0719041

Lab Number : **02533737**

Unique Number : 5514736

Test Package : IND 2 (Additional Tests: TAN Man)

Received : 17 Jan 2023

Tested : 18 Jan 2023

Diagnosed : 18 Jan 2023 - Bill Quesnel

Bruce Power - Bruce A PdM

P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615'

Tiverton, ON

CA N0G 2T0

Contact: Pierre Adouki

pierre.adouki@brucepower.com

T: (519)361-2673

F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.