




PROBLEM SUMMARY

Sample Rating Trend



ADDITIVES




Area
[197133]
 Machine Id
LOK-G1-GEBR


Component
Bearing
 Fluid
ESSO TERESSO ISO 68 (27 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Additives



RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Phosphorus	ppm	ASTM D5185(m)	0.7	▲ 132	32
Zinc	ppm	ASTM D5185(m)	0	▲ 75	57
Sulfur	ppm	ASTM D5185(m)	1315	▲ 1689	2098
Particles >4µm		ASTM D7647	>10000	▲ 34765	▲ 59917
Particles >6µm		ASTM D7647	>2500	▲ 3121	▲ 3339
Oil Cleanliness		ISO 4406 (c)	>20/18/14	▲ 22/19/13	▲ 23/19/11

Customer Id: NEWSTJ
 Sample No.: WC0455785
 Lab Number: 02535347
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1
 (289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

22 Jun 2022 Diag: Kevin Marson

WEAR



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Tin ppm levels are abnormal. Antimony ppm levels are noted. Bearing wear is indicated. Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



14 Dec 2021 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



17 Jun 2021 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area
[197133]
 Machine Id
LOK-G1-GEBR

Component
Bearing
 Fluid
ESSO TERESSO ISO 68 (27 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0455785	WC0328040	WC0445293
Sample Date	Client Info		13 Jan 2023	22 Jun 2022	14 Dec 2021
Machine Age	hrs	Client Info	0	8	8
Oil Age	hrs	Client Info	0	8	0
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m) >63	<1	4	3
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	0	0	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >2	0	0	<1
Lead	ppm	ASTM D5185(m) >161	5	<1	<1
Copper	ppm	ASTM D5185(m) >13	3	9	8
Tin	ppm	ASTM D5185(m) >27	5	▲ 41	5
Antimony	ppm	ASTM D5185(m)	<1	▲ 3	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES






	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 4.5	0	0	<1
Barium	ppm	ASTM D5185(m) 0.4	0	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m) 0	0	0	0
Calcium	ppm	ASTM D5185(m) 0	0	0	<1
Phosphorus	ppm	ASTM D5185(m) 0.7	▲ 132	32	4
Zinc	ppm	ASTM D5185(m) 0	▲ 75	57	51
Sulfur	ppm	ASTM D5185(m) 1315	▲ 1689	2098	2145
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >12	2	<1	<1
Sodium	ppm	ASTM D5185(m)	0	0	0
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 34765	▲ 59917	▲ 30672
Particles >6µm	ASTM D7647	>2500	▲ 3121	▲ 3339	797
Particles >14µm	ASTM D7647	>160	45	13	19
Particles >21µm	ASTM D7647	>40	9	1	5
Particles >38µm	ASTM D7647	>10	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 22/19/13	▲ 23/19/11	▲ 22/17/11




FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.17	0.15	0.13






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	68	66.3	68.0	68.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0455785 **Received** : 25 Jan 2023
Lab Number : **02535347** **Diagnosed** : 27 Jan 2023
Unique Number : 5516346 **Diagnostician** : Bill Quesnel
Test Package : IND 2 (Additional Tests: PrtCount, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com
 T:
 F: (709)737-2926