



FUEL REPORT

Sample Rating Trend


ISO



Area
[143032]
Machine Id
74566859

Component
Diesel Fuel
Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.

Corrosion

(not applicable)

Contaminants

Particles >6µm are severely high. Particles >4µm are severely high. Oil Cleanliness are severely high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. The water content is negligible.

Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			CU0020929	---	---
Sample Date	Client Info			07 Feb 2023	---	---
Machine Age	hrs	Client Info		45	---	---
Sample Status				SEVERE	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.843	---	---
Fuel Color	text	Visual Screen*	Yellow	Pink	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.6	---	---
Pensky-Martens Flash Point	°C	ASTM D7215*	52	58.6	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	7	---	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	171	---	---
5% Distillation Point	°C	ASTM D2887*		194	---	---
10% Distill Point	°C	ASTM D2887*	201	203	---	---
15% Distillation Point	°C	ASTM D2887*		210	---	---
20% Distill Point	°C	ASTM D2887*	216	218	---	---
30% Distill Point	°C	ASTM D2887*	230	232	---	---
40% Distill Point	°C	ASTM D2887*	243	247	---	---
50% Distill Point	°C	ASTM D2887*	255	261	---	---
60% Distill Point	°C	ASTM D2887*	267	276	---	---
70% Distill Point	°C	ASTM D2887*	280	292	---	---
80% Distill Point	°C	ASTM D2887*	295	309	---	---
85% Distillation Point	°C	ASTM D2887*		319	---	---
90% Distill Point	°C	ASTM D2887*	310	330	---	---
95% Distillation Point	°C	ASTM D2887*		344	---	---
Final Boiling Point	°C	ASTM D2887*	341	362	---	---






IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	36	---	---
Cetane Index		ASTM D4737*	<40.0	47	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	<1	---	---
Sodium	ppm	ASTM D5185(m)	<0.1	0	---	---
Potassium	ppm	ASTM D5185(m)	<0.1	0	---	---
Water	%	ASTM D6304*	<0.05	0.003	---	---
ppm Water	ppm	ASTM D6304*	<500	30.8	---	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	32664	---	---
Particles >6µm		ASTM D7647	>640	8246	---	---
Particles >14µm		ASTM D7647	>80	259	---	---
Particles >21µm		ASTM D7647	>20	51	---	---
Particles >38µm		ASTM D7647	>4	2	---	---
Particles >71µm		ASTM D7647	>3	0	---	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	22/20/15	---	---






FUEL REPORT



HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	---
Nickel	ppm	ASTM D5185(m)	<0.1	0	---
Lead	ppm	ASTM D5185(m)	<0.1	0	---
Vanadium	ppm	ASTM D5185(m)	<0.1	0	---
Iron	ppm	ASTM D5185(m)	<0.1	<1	---
Calcium	ppm	ASTM D5185(m)	<0.1	<1	---
Magnesium	ppm	ASTM D5185(m)	<0.1	<1	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	<1	---
Zinc	ppm	ASTM D5185(m)	<0.1	2	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CUMMINS CANADA ULC - GENERATOR DIVISION
Sample No. : CU0020929 **Received** : 09 Feb 2023 7175 PACIFIC CIRCLE
Lab Number : 02538509 **Diagnosed** : 13 Feb 2023 MISSISSAUGA, ON
Unique Number : 5527509 **Diagnostician** : Kevin Marson CA L5T 2A5
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)
 Contact: Elisia Johnson
 elisia.johnson@cummins.com
 T: (905)795-0050
 F: (905)795-9252