




PROBLEM SUMMARY


Area
COR
 Machine Id
LONGGEN3BRGDS
 Component
Bearing
 Fluid
SHELL TURBO T ISO 68 (25 LTR)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ 75944	5843	▲ 35625
Particles >6µm	ASTM D7647	>2500	▲ 14013	1180	▲ 9852
Particles >14µm	ASTM D7647	>160	▲ 243	72	▲ 446
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 23/21/15	20/17/13	▲ 22/20/16

Customer Id: ALGMIS
 Sample No.: WC0681491
 Lab Number: 02546676
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

06 Oct 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



23 Feb 2022 Diag: Kevin Marson

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



22 Sep 2021 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
COR
Machine Id
LONGGEN3BRGDS

Component
Bearing
Fluid
SHELL TURBO T ISO 68 (25 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		WC0681491	WC0681477	WC0447248
Sample Date	Client Info		16 Mar 2023	06 Oct 2022	23 Feb 2022
Machine Age	mths	Client Info	305	300	292
Oil Age	mths	Client Info	5	33	25
Oil Changed	Client Info		Not Changed	Changed	Not Changed
Sample Status			ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2
PQ	ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m) >20	1	0	0
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	0	0	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >20	0	0	0
Lead	ppm	ASTM D5185(m) >20	<1	0	<1
Copper	ppm	ASTM D5185(m) >20	4	<1	<1
Tin	ppm	ASTM D5185(m) >20	<1	<1	<1
Antimony	ppm	ASTM D5185(m)	<1	0	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185(m)	<1	0	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	0
Calcium	ppm	ASTM D5185(m)	0	0	0
Phosphorus	ppm	ASTM D5185(m)	<1	0	<1
Zinc	ppm	ASTM D5185(m)	3	<1	1
Sulfur	ppm	ASTM D5185(m)	18	23	21
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185(m) >15	0	0	0
Sodium	ppm	ASTM D5185(m)	<1	0	0
Potassium	ppm	ASTM D5185(m) >20	0	0	<1
Water	%	ASTM D6304* >2	0.001	0.001	0.00
ppm Water	ppm	ASTM D6304*	8.4	7.4	0.00


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	>10000	▲ 75944	5843	▲ 35625
Particles >6µm	ASTM D7647	>2500	▲ 14013	1180	▲ 9852
Particles >14µm	ASTM D7647	>160	▲ 243	72	▲ 446
Particles >21µm	ASTM D7647	>40	51	19	▲ 82
Particles >38µm	ASTM D7647	>10	2	1	2
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 23/21/15	20/17/13	▲ 22/20/16




OIL ANALYSIS REPORT


Particle Trend




Water




PQ



Water



Viscosity @ 40°C




FLUID DEGRADATION

method	limit/base	current	history 1	history 2
Acid Number (AN) mg KOH/g	ASTM D974* .05	0.06	0.03	0.07
VISUAL				
method	limit/base	current	history 1	history 2
White Metal	scalar Visual* NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual* NONE	NONE	NONE	NONE
Precipitate	scalar Visual* NONE	NONE	NONE	NONE
Silt	scalar Visual* NONE	NONE	NONE	NONE
Debris	scalar Visual* NONE	NONE	NONE	NONE
Sand/Dirt	scalar Visual* NONE	NONE	NONE	NONE
Appearance	scalar Visual* NORML	NORML	NORML	NORML
Odor	scalar Visual* NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual* >2	NEG	NEG	NEG
Free Water	scalar Visual*	NEG	NEG	NEG

FLUID PROPERTIES


method	limit/base	current	history 1	history 2
Visc @ 40°C cSt	ASTM D7279(m) 68	65.8	65.8	66.5

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0681491 **Received** : 21 Mar 2023
Lab Number : 02546676 **Diagnosed** : 23 Mar 2023
Unique Number : 5551686 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KF, PrtCount, TAN Man)

354 DAVIS ROAD
 OAKVILLE, ON
 CA L6J 2X1
 Contact: Antonino Champ Fernando
 antoninoChamp.fernando@algonquinpower.com
 T: (905)465-7065
 F: x: