




# PROBLEM SUMMARY

Sample Rating Trend

DEGRADATION




Area  
**[01565753]**  
 Machine Id  
**D3310B GAS COMPRESSOR SEAL OIL**  
 Component  
**Compressor**  
 Fluid  
**IRVING D & E ISO 32 (--- GAL)**




## COMPONENT CONDITION SUMMARY


### ▲ Varnish Potential



### ▲ Remaining Life (RULER)



### ● Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Anti-Oxidant 2	%	ASTM D6971*	<25	▲ 19	▲ 14
MPC Varnish Potential	Scale	ASTM D7843(m)*	>15	▲ 48	▲ 56
					▲ 49

Customer Id: HIBSTJ  
 Sample No.: PP  
 Lab Number: 02551730  
 Test Package: AOM 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Bill Quesnel CLS, OMA II, MLA-III, LLA-I +1  
 (289)291-4641 x4641  
[Bill.Quesnel@wearcheck.com](mailto:Bill.Quesnel@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Filter Fluid	---	---	?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

## HISTORICAL DIAGNOSIS

### DEGRADATION



#### 29 Jan 2023 Diag: Bill Quesnel

We recommend that you sweeten the oil by draining off half the system oil (50%) and replacing with new oil. We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a light amount of silt (particulates < 14 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The water content is negligible. Linear Sweep Voltammetry (RULER– ASTM D6971) testing indicates one of the anti-oxidants present in the oil will soon be depleted. The AN level is acceptable for this fluid.

view report



### INSOLUBLES



#### 15 Nov 2022 Diag: Bill Quesnel

We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The AN level is acceptable for this fluid.

view report



### INSOLUBLES



#### 09 Nov 2021 Diag: Bill Quesnel

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. No other corrective action is recommended at this time. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a light amount of silt (particulates < 14 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a light concentration of varnish present. The water content is negligible. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area  
**[01565753]**  
 Machine Id  
**D3310B GAS COMPRESSOR SEAL OIL**  
 Component  
**Compressor**  
 Fluid  
**IRVING D & E ISO 32 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition.

### ▲ Wear

All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system.

### ▲ Contaminants

There is a light amount of silt (particulates < 14 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The water content is negligible.

### ▲ Oil Condition

Linear Sweep Voltammetry (RULER- ASTM D6971) testing indicates a low amount of one of the anti-oxidants present in the oil, however, the other anti-oxidant(s) are still performing adequately. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PP	PP	PP
Sample Date	Client Info	<b>16 Apr 2023</b>	29 Jan 2023	15 Nov 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	<b>0</b>	0	0
Iron	ppm	ASTM D5185(m) >50	<b>2</b>	2
Chromium	ppm	ASTM D5185(m) >5	<b>0</b>	0
Nickel	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0
Aluminum	ppm	ASTM D5185(m) >15	<b>&lt;1</b>	0
Lead	ppm	ASTM D5185(m) >65	<b>0</b>	0
Copper	ppm	ASTM D5185(m) >65	<b>0</b>	0
Tin	ppm	ASTM D5185(m) >10	<b>0</b>	<1
Antimony	ppm	ASTM D5185(m)	<b>&lt;1</b>	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0.0	<b>0</b>	<1
Barium	ppm	ASTM D5185(m) 0.2	<b>0</b>	0
Molybdenum	ppm	ASTM D5185(m) 0.0	<b>0</b>	0
Manganese	ppm	ASTM D5185(m)	<b>0</b>	0
Magnesium	ppm	ASTM D5185(m) 0.3	<b>0</b>	0
Calcium	ppm	ASTM D5185(m) 2.0	<b>0</b>	0
Phosphorus	ppm	ASTM D5185(m) 4.6	<b>&lt;1</b>	<1
Zinc	ppm	ASTM D5185(m) 7.4	<b>1</b>	1
Sulfur	ppm	ASTM D5185(m)	<b>300</b>	305
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >35	<b>&lt;1</b>	<1
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	0
Water	%	ASTM D6304* >0.1	<b>0.001</b>	0.003
ppm Water	ppm	ASTM D6304* >1000	<b>12.3</b>	27.9


## INFRA-RED

method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	<b>0</b>	0
Nitration	Abs/cm	ASTM D7624*	<b>2.1</b>	2.2
Sulfation	Abs/.1mm	ASTM D7415*	<b>11.4</b>	12.1




# OIL ANALYSIS REPORT


## ▲ Varnish Potential




## ▲ Remaining Life (RULER)




## ● Particle Count



## ● Particle Trend



## Acid Number




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	● <b>12891</b>	● 12015	1537
Particles >6µm	ASTM D7647	>2500	● <b>2863</b>	2250	200
Particles >14µm	ASTM D7647	>320	<b>81</b>	145	10
Particles >21µm	ASTM D7647	>80	<b>20</b>	46	2
Particles >38µm	ASTM D7647	>20	<b>2</b>	4	0
Particles >71µm	ASTM D7647	>4	<b>0</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	● <b>21/19/14</b>	● 21/18/14	18/15/10

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm ASTM D7414*		<b>3.4</b>	3.3	3.4
Acid Number (AN)	mg KOH/g ASTM D974*	0.10	<b>0.07</b>	0.05	0.09
Anti-Oxidant 1	% ASTM D6971*	<25	<b>55</b>	66	59
Anti-Oxidant 2	% ASTM D6971*	<25	▲ <b>19</b>	▲ 14	35
MPC Varnish Potential	Scale ASTM D7843(m)*	>15	▲ <b>48</b>	▲ 56	▲ 49

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar Visual*	NONE	<b>VLITE</b>	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar Visual*	>0.1	<b>.2%</b>	NEG	NEG
Free Water	scalar Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	32.5	<b>30.8</b>	31.8	38.1
Visc @ 100°C	cSt ASTM D7279(m)	5.4	<b>5.6</b>	5.7	5.9
Viscosity Index (VI)	Scale ASTM D2270*	99	<b>121</b>	120	95

## SAMPLE IMAGES



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
 Sample No. : PP  
 Lab Number : **02551730**  
 Unique Number : 5564745  
 Test Package : AOM 2



**HIBERNIA MGMT & DEVELOPMENT CO. LTD**  
 SUITE 1000,, 100 NEW GOWER STREET  
 ST.JOHNS, NL  
 CA A1C 6K3  
 Contact: Christopher Michelau  
 christopher.j.michelau@exxonmobil.com  
 T:  
 F: (709)722-3766

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.



# FERROGRAPHY REPORT

Area  
**[01565753]**  
 Machine Id  
**D3310B GAS COMPRESSOR SEAL OIL**  
 Component  
**Compressor**  
 Fluid  
**IRVING D & E ISO 32 (--- GAL)**




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		3.7	2.8	2.6
Small Particles		DR-Ferr*		3.5	3.0	2.6
Total Particles		DR-Ferr*	>---	7.2	5.8	5.2
Large Particles Percentage	%	DR-Ferr*		2.8	0	0
Severity Index		DR-Ferr*		1	1	0


FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		1	1	2
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*				1
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		1		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*				
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		2	1	1
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*				2

### WEAR


All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system.







MPC (Varnish Test)



Sample Color & Clarity

