




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
PAB DIESEL (S/N 69-E1-1081)

Component
Electromotive Diesel

Fluid
PETRO CANADA RALUBE 40 CFS (350 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0455696	WC0316876	WC933596
Sample Date	Client Info		21 Feb 2023	17 Jun 2021	24 Jan 2017
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	ATTENTION

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m) >75	10	10	6
Chromium	ppm	ASTM D5185(m) >10	<1	<1	<1
Nickel	ppm	ASTM D5185(m) >5	<1	<1	0
Titanium	ppm	ASTM D5185(m)	<1	0	0
Silver	ppm	ASTM D5185(m) >5	0	<1	0
Aluminum	ppm	ASTM D5185(m) >7	2	2	2
Lead	ppm	ASTM D5185(m) >50	4	4	3
Copper	ppm	ASTM D5185(m) >100	8	7	6
Tin	ppm	ASTM D5185(m) >10	2	1	<1
Antimony	ppm	ASTM D5185(m)	<1	0	1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<1	<1	<1
Barium	ppm	ASTM D5185(m) 0	0	<1	<1
Molybdenum	ppm	ASTM D5185(m) 0	1	1	1
Manganese	ppm	ASTM D5185(m) 0	<1	<1	<1
Magnesium	ppm	ASTM D5185(m) 25	26	25	21
Calcium	ppm	ASTM D5185(m) 4300	4432	4337	4450
Phosphorus	ppm	ASTM D5185(m) 1.6	2	3	3
Zinc	ppm	ASTM D5185(m) 2	5	5	4
Sulfur	ppm	ASTM D5185(m) 1500	2863	3343	4767
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >5	5	5	5
Sodium	ppm	ASTM D5185(m)	20	22	31
Potassium	ppm	ASTM D5185(m) >20	21	22	24

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	0	0	0
Nitration	Abs/cm	ASTM D7624*	11.7	12.0	12.1
Sulfation	Abs.1mm	ASTM D7415*	13.6	14.1	16.5



OIL ANALYSIS REPORT







FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	ASTM D7414*	>25	9.3	9.6	8.7
Acid Number (AN)	mg KOH/g	ASTM D974*	1.50	1.61	---	---
Base Number (BN)	mg KOH/g	ASTM D2896*	14.0	12.90	13.16	14.25

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	▲ VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	---	NONE
Precipitate	scalar	Visual*	NONE	NONE	---	NONE
Silt	scalar	Visual*	NONE	NONE	---	NONE
Debris	scalar	Visual*	NONE	NONE	---	▲ VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	---	NONE
Appearance	scalar	Visual*	NORML	NORML	---	NORML
Odor	scalar	Visual*	NORML	NORML	---	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	142.2	119	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	14.8	13.2	13.0	13.7
Viscosity Index (VI)	Scale	ASTM D2270*	104	105	---	---

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0455696
Lab Number : **02554016**
Unique Number : 5567031
Test Package : MOB 2 (Additional Tests: ICP-NewOil, KV40, PQ, PriCount, TAN Auto, TAN Man, VI, Visual)

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Glenn Whitty
 gwhitty@newfoundlandpower.com
 T: (709)737-5326
 F: (709)737-5867

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.