

COOLANT REPORT

HUMBER RIVER HOSPITAL [78791] Machine Id 2013806810

Component

Coolant

EXTENDED LIFE COOLANT (--- GAL)

Sample Rating Trend WEAR Jinf022 April 023

DIAGNOSIS

Recommendation

The coolant change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Corrosion

Aluminum ppm levels are abnormal. The high metal levels indicate corrosion in the system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

			Jan 2022	Apr2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0018548	WA0017485	
Sample Date		Client Info		18 Apr 2023	31 Jan 2022	
Machine Age	hrs	Client Info		94	16	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.068	1.067	
рН	Scale 0-14	ASTM D1287*	9.0	8.19	8.23	
Nitrites	ppm	Alcan Test Kit*		680	800	
Reserve Alkalinity	Scale 0-20	ASTM D1121*		4.7	4.7	
Percentage Glycol	%	ASTM D3321*	50	50.2	50.0	
Freezing Point	°C	ASTM D3321*	-40	-35	-37	
Carboxylate						
CORROSION INHI	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		22	11	
Phosphorus	ppm	ASTM D5185(m)		11	12	
Boron	ppm	ASTM D5185(m)		33	58	
Molybdenum	ppm	ASTM D5185(m)		388	410	
CORROSION		method	limit/base	current	history1	history2
						,
Iron	ppm	ASTM D5185(m)	>15	1	1	
Aluminum	ppm	ASTM D5185(m)		<u>^</u> 23	<u> 13</u>	
Copper	ppm	ASTM D5185(m)	>10	2	<1 2	
Lead	ppm	()		<1		
Tin	ppm	ASTM D5185(m)	>10	0	<1	
Silver Zinc	ppm	ASTM D5185(m)	>10	0 4	<1 4	
-	ppm	ASTM D5185(m)		4		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		3324	2321	
Potassium	ppm	ASTM D5185(m)		78	69	
SCALE POTENTIA	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	16	7	
Magnesium	ppm	ASTM D5185(m)	>40	2	2	
Hardness	mg/L CaCO3	In-house*	<75	49	26	
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*	Orange/R	Red	Red	
Coolant Appearance		Visual*	Clear	Clear	Clear	
Color					1 1 1 1 1 1 1 1 1 1	no image
Bottom						no image



COOLANT REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5568273

: WA0018548 : 02555258

Test Package : COOL

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : 03 May 2023

Diagnosed : 05 May 2023 Diagnostician : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems 10 Diesel Drive

Toronto, ON **CA M8W 2T8** Contact: David Gilkes dgilkes@wajax.com

T: (416)259-3281 F: (416)251-6191