

COOLANT REPORT

HUMBER RIVER HOSPITAL [85092]

Component

Coolant

CONVENTIONAL COOLANT (--- GAL)

D16*069150*C3*A

Sample Rating Trend



DIAGNOSIS

Recommendation

The coolant change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Corrosion

Iron ppm levels are severe. Aluminum ppm levels are abnormal. The iron level is high indicating rust in the system which clogs the cooling system. The high metal levels indicate corrosion in the system.

▲ Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

The coolant is cloudy indicating either an overconcentration of coolant additives, or a mixing of incompatible coolant technologies. The nitrite level is acceptable. The pH is low which causes rust formation.

			Jan 2022	AprŽ023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0018501	WA0017181	
Sample Date		Client Info		26 Apr 2023	26 Jan 2022	
Machine Age	hrs	Client Info		267	227	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				SEVERE	SEVERE	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.064	1.065	
рН	Scale 0-14	ASTM D1287*	9.5	7.80	▲ 7.23	
Nitrites	ppm	Alcan Test Kit*	1500	880	1720	
Reserve Alkalinity	Scale 0-20	ASTM D1121*	8.5	3.3	2.7	
Percentage Glycol	%	ASTM D3321*	50	47.1	48.0	
Freezing Point	°C	ASTM D3321*	-40	-28	-34	
Carboxylate						
CORROSION INHI	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		35	46	
Phosphorus	ppm	ASTM D5185(m)		39	47	
Boron	ppm	ASTM D5185(m)		316	304	
Molybdenum	ppm	ASTM D5185(m)		2	4	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	210	1 00	
Aluminum	ppm	ASTM D5185(m)	>10	4 39	6	
Copper	ppm	ASTM D5185(m)	>10	5	<1	
Lead	ppm	ASTM D5185(m)	>10	2	<1	
Tin	ppm	ASTM D5185(m)	>10	<1	<1	
Silver	ppm	ASTM D5185(m)	>10	0	<1	
Zinc	ppm	ASTM D5185(m)		42	9	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		2223	1767	
Potassium	ppm	ASTM D5185(m)		262	303	
SCALE POTENTIA	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	12	6	
Magnesium	ppm	ASTM D5185(m)	>40	5	4	
Hardness	mg/L CaCO3	In-house*	<75	49	31	
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*	Green	Green	Green	
Coolant Appearance		Visual*	Clear	Very cld	△ Cloudy	
Color						no image


Bottom

Contact/Location: David Gilkes - HARTOR

no image



COOLANT REPORT





ISO 17025:2017 Accredited Laboratory

Sample No. Lab Number **Unique Number**

: WA0018501 : 02555618

Received

Diagnosed

: 04 May 2023 : 05 May 2023

Diagnostician : Kevin Marson

Test Package : COOL (Additional Tests: PQ)

: 5568633

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

10 Diesel Drive Toronto, ON **CA M8W 2T8** Contact: David Gilkes dgilkes@wajax.com T: (416)259-3281 F: (416)251-6191