



PROBLEM SUMMARY

Sample Rating Trend


ISO



Machine Id
BFP - UNIT 5 THRUST BEARING (S/N 375301)


Component
Circulating Thrust Bearing

Fluid
SHELL TURBO T ISO 46 (30 LTR)




COMPONENT CONDITION SUMMARY

Particle Trend



Viscosity @ 40°C




RECOMMENDATION

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	109396	1650	837
Particles >6µm	ASTM D7647	>2500	41979	343	170
Particles >14µm	ASTM D7647	>160	4162	33	26
Particles >21µm	ASTM D7647	>40	1297	7	12
Particles >38µm	ASTM D7647	>10	33	1	1
Oil Cleanliness	ISO 4406 (c)	>20/18/14	24/23/19	18/16/12	17/15/12
Appearance	scalar	Visual*	WGOIL	NORML	NORML
Free Water	scalar	Visual*	1%	NEG	NEG
Visc @ 40°C	cSt	ASTM D7279(m)	46	45.8	46.5

PrtFilter



Customer Id: NALGRA
Sample No.: WC0701183
Lab Number: 02556553
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We advise an early resample to confirm this situation.
Alert	---	---	?	NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit.

HISTORICAL DIAGNOSIS

01 Jun 2021 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



11 May 2020 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



25 Jul 2017 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





OIL ANALYSIS REPORT

Sample Rating Trend


ISO



Machine Id
BFP - UNIT 5 THRUST BEARING (S/N 375301)

Component
Circulating Thrust Bearing

Fluid
SHELL TURBO T ISO 46 (30 LTR)



DIAGNOSIS

Recommendation

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit.

Wear

All component wear rates are normal.


Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Free water present.

Fluid Condition

Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Particle Filter (Magn: 100 x)



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0701183	WC0509216	WC0455066
Sample Date	Client Info		25 Apr 2023	01 Jun 2021	11 May 2020
Machine Age	yrs	Client Info	0	0	0
Oil Age	yrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >85	11	<1	<1
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	0	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	<1
Aluminum	ppm	ASTM D5185(m) >40	0	0	<1
Lead	ppm	ASTM D5185(m) >60	0	0	0
Copper	ppm	ASTM D5185(m) >7	<1	<1	<1
Tin	ppm	ASTM D5185(m) >40	5	<1	0
Antimony	ppm	ASTM D5185(m)	<1	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 4.0	0	<1	0
Barium	ppm	ASTM D5185(m) 0	0	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	<1	0	0
Magnesium	ppm	ASTM D5185(m) 0	0	0	<1
Calcium	ppm	ASTM D5185(m) 0	0	6	3
Phosphorus	ppm	ASTM D5185(m) 2.1	0	46	24
Zinc	ppm	ASTM D5185(m) 2.0	1	53	30
Sulfur	ppm	ASTM D5185(m) 1300	161	146	231
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >20	<1	0	0
Sodium	ppm	ASTM D5185(m)	0	<1	0
Potassium	ppm	ASTM D5185(m) >20	0	<1	<1

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	109396	1650	837
Particles >6µm	ASTM D7647	>2500	41979	343	170
Particles >14µm	ASTM D7647	>160	4162	33	26
Particles >21µm	ASTM D7647	>40	1297	7	12
Particles >38µm	ASTM D7647	>10	33	1	1
Particles >71µm	ASTM D7647	>3	2	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	24/23/19	18/16/12	17/15/12

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* .05	0.05	0.08	0.08




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	▲ NORML	NORML
Emulsified Water	scalar	Visual*	>2	▲ .2%	NEG
Free Water	scalar	Visual*		▲ 1%	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	▲ 101	45.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Nalcor Energy - Grand Falls-Windsor**
Sample No. : WC0701183 **Received** : 10 May 2023 25 Hardy Avenue
Lab Number : 02556553 **Diagnosed** : 15 May 2023 Grand Falls-Windsor, NL
Unique Number : 5577593 **Diagnostician** : Kevin Marson CA A2A 2P8
Test Package : IND 2 (Additional Tests: BottomAnalysis, FilterPatch, PrtCount, PrtFilter, TAN Man) Contact: Phillip Winsor
philipwinsor@nlh.nl.ca
T: (709)486-8714
F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.