

# **OIL ANALYSIS REPORT**

Sample Rating Trend

WEAR

Machine Id MOTOR 1 NDE Component Non-Drive End Bearing

Fluid GEAR OIL ISO 220 (35 LTR)

## DIAGNOSIS

### A Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) GEAR OIL ISO 220. Please confirm.

#### 🔺 Wear

Lead ppm levels are abnormal. Bearing wear is indicated.

#### Contamination

There is no indication of any contamination in the oil.

# Fluid Condition


The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0811975		
Sample Date		Client Info		17 May 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	4		
Chromium	ppm	ASTM D5185(m)	>20	0		
Nickel	ppm	ASTM D5185(m)	>20	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>20	0		
Lead	ppm	ASTM D5185(m)	>20	<b>4</b> 3		
Copper	ppm	ASTM D5185(m)	>20	4		
Tin	ppm	ASTM D5185(m)	>20	6		
Antimony	ppm	ASTM D5185(m)		6		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	50	54		
Barium	ppm	ASTM D5185(m)	15	0		
Molybdenum	ppm	ASTM D5185(m)	15	0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)	50	<1		
Calcium	ppm	ASTM D5185(m)	50	0		
Phosphorus	ppm	ASTM D5185(m)	350	269		
Zinc	ppm	ASTM D5185(m)	100	7		
Sulfur	ppm	ASTM D5185(m)	12500	10703		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	3		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	0		



# **OIL ANALYSIS REPORT**

VISUAL



	White Metal	scalar	Visual*	NONE	NONE		
	Yellow Metal		Visual*	NONE	NONE		
	Precipitate	scalar	Visual*	NONE	NONE		
	Silt	scalar	Visual*	NONE	NONE		
	Debris	scalar	Visual*	NONE	NONE		
	Sand/Dirt	scalar	Visual*	NONE	NONE		
May17/23	Appearance	scalar	Visual*	NORML	NORML		
May1	Odor	scalar	Visual*	NORML	NORML		
	Emulsified Water	scalar	Visual*	>2	NEG		
1	Free Water	scalar	Visual*		NEG		
	FLUID PROPERT	IES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D7279(m)	220	221		
	SAMPLE IMAGES	6	method	limit/base	current	history1	history2
May17/23 +	Color					no image	no image
	Bottom					no image	no image
	Ferrous Alloys			May17/23			
	Non-ferrous Metal			May17/23			
	2 230 2 200 3 210 200 4bnormal 190 527 60 60 60 60 60 60 60 60 60 60			May17/23			
oratory nple No. Number ue Number t Package		Recei Teste Diagr	ived :18 ed :18	igton, ON L7 3 May 2023 3 May 2023 May 2023 - Ke			hnical Services bbWood Drive. Sudbury, ON CA P3C 3B7 ct: Nick Walker

limit/base

current

method

history1

history2

Test Package : IND 1 To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Report Id: CENSUD [WCAMIS] 02558356 (Generated: 04/23/2024 08:31:58) Rev: 1

CALA

ISO 17025:2017 Accredited Laboratory

F: (795)690-9010 Contact/Location: Nick Walker - CENSUD Page 2 of 2

nwalker@northpoints.com T: (705)499-2387