PROBLEM SUMMARY

Sample Rating Trend



ISO

Area
MANITOU FALLS GS
Machine Id
FP2G4
Component
Thrust Bearing
Fluid
ESSO TERESSO ISO 46 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Particles >4µm		ASTM D7647	>10000	▲ **27641**	---	939
Particles >6µm		ASTM D7647	>2500	▲ **3906**	---	276
Oil Cleanliness		ISO 4406 (c)	>20/18/14	▲ **22/19/14**	---	17/15/12

PrtFilter



Customer Id: ONTKEE
Sample No.: WC0806469
Lab Number: 02559004
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

HISTORICAL DIAGNOSIS

01 Dec 2021 Diag: Kevin Marson

VIS DEBRIS

This is a baseline read-out on the submitted sample.{not applicable} a light concentration of debris was filtered from the sample. {not applicable}

view report

29 Mar 2021 Diag: Kevin Marson

NORMAL

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) R&O OIL ISO 46. Please confirm. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

08 Jul 2020 Diag: Kevin Marson

VISUAL METAL

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.Light concentration of visible metal present. All other component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. NOTE: An increase in the particle count is noted. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
MANITOU FALLS GS
Machine Id
FP2G4
Component
Thrust Bearing
Fluid
ESSO TERESSO ISO 46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Particle Filter (Magn: 200 x)

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0806469**	PP	WC0560629
Sample Date		Client Info		**09 May 2023**	01 Dec 2021	29 Mar 2021
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>2	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		**0**	---	---
Iron	ppm	ASTM D5185(m)	>85	**1**	35	11
Chromium	ppm	ASTM D5185(m)	>20	**<1**	0	0
Nickel	ppm	ASTM D5185(m)	>20	**0**	<1	<1
Titanium	ppm	ASTM D5185(m)		**0**	0	0
Silver	ppm	ASTM D5185(m)		**0**	0	<1
Aluminum	ppm	ASTM D5185(m)	>40	**0**	<1	<1
Lead	ppm	ASTM D5185(m)	>60	**<1**	5	2
Copper	ppm	ASTM D5185(m)	>7	**2**	2	2
Tin	ppm	ASTM D5185(m)	>40	**<1**	1	<1
Antimony	ppm	ASTM D5185(m)		**0**	<1	<1
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	**0**	<1	<1
Barium	ppm	ASTM D5185(m)		**0**	0	0
Molybdenum	ppm	ASTM D5185(m)	0	**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	<1	<1
Magnesium	ppm	ASTM D5185(m)	0	**0**	0	0
Calcium	ppm	ASTM D5185(m)	0	**0**	<1	<1
Phosphorus	ppm	ASTM D5185(m)	2.4	**2**	4	2
Zinc	ppm	ASTM D5185(m)	0	**2**	<1	1
Sulfur	ppm	ASTM D5185(m)		**663**	1922	1958
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>20	**3**	14	10
Sodium	ppm	ASTM D5185(m)		**<1**	2	<1
Potassium	ppm	ASTM D5185(m)	>20	**0**	<1	<1

OIL ANALYSIS REPORT

Particle Count



Particle Trend



Acid Number



Viscosity @ 40°C



PQ



FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ **27641**	---	939
Particles >6µm		ASTM D7647	>2500	▲ **3906**	---	276
Particles >14µm		ASTM D7647	>160	**81**	---	24
Particles >21µm		ASTM D7647	>40	**14**	---	4
Particles >38µm		ASTM D7647	>10	**1**	---	0
Particles >71µm		ASTM D7647	>3	**1**	---	0
Oil Cleanliness		ISO 4406 (c)	>20/18/14	▲ **22/19/14**	---	17/15/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	**0.04**	---	0.07

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	NONE
Silt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	▲ LIGHT	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>2	**NEG**	---	NEG
Free Water	scalar	Visual*		**NEG**	---	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	**46.0**	---	47.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					
PrtFilter					

ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0806469 **Received** : 23 May 2023
Lab Number : 02559004 **Diagnosed** : 24 May 2023
Unique Number : 5580044 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: BottomAnalysis, FilterPatch, PrtCount, PrtFilter, TAN Man)

Ontario Power Generation
KENORA PRODUCTION CENTRE, 200-60 FOURTEENTH ST N.
KENORA, ON
CA P9N 4M9
Contact: Josh Robinson
josh.robinson@opg.com
T:
F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.