

FUEL REPORT

Sample Rating Trend





Component Center Jet Fuel Fluid JET FUEL Type A (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

{not applicable}

Contamination

ISO Cleanliness Code (ISO 4406:1999): 18/16/11; Cumulative particle counts >4 μ m = 1545, >6 μ m = 336, >14 μ m = 19, >21 μ m = 5, >38 μ m = 0, >71 μ m = 0.


Fluid Condition

{not applicable}

				May2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0800088		
Sample Date		Client Info		23 May 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	1545		
Particles >6µm		ASTM D7647	>1300	336		
Particles >14µm		ASTM D7647	>160	19		
Particles >21µm		ASTM D7647	>40	5		
Particles >38µm		ASTM D7647	>10	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	18/16/11		
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					no image	no image
Bottom				(\circ)	no image	no image



FUEL REPORT



: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Laboratory CALA Sample No. : WC0800088 Received : 24 May 2023 Lab Number : 02559331 Diagnosed : 25 May 2023 ISO 17025:2017 Accredited Laboratory Unique Number : 5580371 Diagnostician : Kevin Marson Test Package : TEST (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

KF Aero 9500 Airport Road Mount Hope, ON CA LOR 1W0 Contact: Justin Lewis j.lewis@kfaero.ca T: (905)679-3313 F: (905)679-4921