

PROBLEM SUMMARY


CAMPBELLFORD PLANT **G3 BULKHEAD**

Component Turbine

PETRO CANADA PURITY FG EP GEAR OIL 100 (40 LTR)

Sample Rating Trend

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS									
Sample Status			SEVERE						
Particles >4µm	ASTM D7647	>2500	37330						
Particles >6µm	ASTM D7647	>640	9784						
Particles >14µm	ASTM D7647	>80	546						
Particles >21µm	ASTM D7647	>20	126						
Oil Cleanliness	ISO 4406 (c)	>18/16/13	22/20/16						

Customer Id: PET412PET Sample No.: WC0774043 Lab Number: 02560147 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS								
Action	Status	Date	Done By	Description				
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.				
Resample			?	Resample in 30-45 days to monitor this situation.				
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.				
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.				
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.				

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT





CAMPBELLFORD PLANT **G3 BULKHEAD**

Component **Turbine**

PETRO CANADA PURITY FG EP GEAR OIL 100 (40 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



				May2023		
SAMPLE INFORM	ATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		WC0774043		
Sample Date		Client Info		17 May 2023		
Machine Age	yrs	Client Info		60		
Oil Age	yrs	Client Info		2		
Oil Changed		Client Info		Not Changd		
Sample Status				SEVERE		
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185(m)	>15	7		
Chromium	ppm	ASTM D5185(m)	>4	0		
Nickel	ppm	ASTM D5185(m)	>2	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>10	<1		
Lead	ppm	ASTM D5185(m)		6		
Copper	ppm	ASTM D5185(m)	>5	2		
Tin	ppm	ASTM D5185(m)	>5	1		
Antimony	ppm	ASTM D5185(m)		<1		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185(m)		0		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		<1		
Magnesium	ppm	ASTM D5185(m)		0		
Calcium	ppm	ASTM D5185(m)		0		
Phosphorus	ppm	ASTM D5185(m)	135	135		
Zinc	ppm	ASTM D5185(m)		11		
Sulfur	ppm	ASTM D5185(m)	660	643		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185(m)	>15	0		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	0		
Water	%	ASTM D6304*	>0.03	0.006		
ppm Water	ppm	ASTM D6304*	>300	60.9		
FLUID CLEANLINE	ESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>2500	37330		
Particles >6µm		ASTM D7647	>640	9784		
Particles >14μm		ASTM D7647	>80	^ 546		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	3		
Dortiolog : 71.m		ACTM D7647	0	^		

ASTM D7647 >3

0


ISO 4406 (c) >18/16/13 **22/20/16**

Particles >71µm

Oil Cleanliness



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited

Laboratory

Sample No. Lab Number **Unique Number**

Test Package

: WC0774043 . 02560147

: 5581187 : IND 2

Received : 29 May 2023 Diagnosed : 29 May 2023 Diagnostician

: Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

1867 ASHBURNHAM DRIVE PETERBOROUGH, ON CA K9L 1P8

Contact: Dan Brown dbrown@peterboroughutilities.ca

> T: (705)933-6893 F: (705)748-3138