




PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION



Machine Id
LSGS SLUICE GATE 2
 Component
Pump Hydraulic System
 Fluid
BIOFLOW AWS 22 (80 GAL)

COMPONENT CONDITION SUMMARY

Acid Number



RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status	SEVERE	ABNORMAL	ATTENTION
Acid Number (AN) mg KOH/g ASTM D974*	5.81	2.49	1.26

Customer Id: PET412PET
 Sample No.: WC0801015
 Lab Number: 02560183
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

12 Aug 2020 Diag: Kevin Marson

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Nickel ppm levels are abnormal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is above the recommended limit. The oil is no longer serviceable.

view report



14 Nov 2018 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
LSGS SLUICE GATE 2
 Component
Pump Hydraulic System
 Fluid
BIOFLOW AWS 22 (80 GAL)

DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The high AN level of the oil indicates the presence of oxi-polymerized products. The AN level is much higher than the recommended limit. The oil is no longer serviceable. NOTE: The color of the oil is darker then previous samples.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0801015	WC0373463	WC985026
Sample Date	Client Info		18 May 2023	12 Aug 2020	14 Nov 2018
Machine Age	yrs	Client Info	8	218	159
Oil Age	yrs	Client Info	8	218	159
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			SEVERE	ABNORMAL	ATTENTION

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.05	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	4	2	<1
Chromium	ppm	ASTM D5185(m)	>20	0	<1	0
Nickel	ppm	ASTM D5185(m)	>20	0	▲ 22	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>20	2	2	1
Copper	ppm	ASTM D5185(m)	>20	<1	17	3
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<1	2	<1
Barium	ppm	ASTM D5185(m)		0	<1	0
Molybdenum	ppm	ASTM D5185(m)		0	<1	<1
Manganese	ppm	ASTM D5185(m)		0	0	<1
Magnesium	ppm	ASTM D5185(m)		0	<1	<1
Calcium	ppm	ASTM D5185(m)		5	16	24
Phosphorus	ppm	ASTM D5185(m)		275	250	242
Zinc	ppm	ASTM D5185(m)		13	28	35
Sulfur	ppm	ASTM D5185(m)		1166	1146	1172
Lithium	ppm	ASTM D5185(m)		<1	<1	0

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	1	<1	<1
Sodium	ppm	ASTM D5185(m)		<1	0	1
Potassium	ppm	ASTM D5185(m)	>20	0	<1	2


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	755	3947	▲ 7808
Particles >6µm	ASTM D7647	>1300	250	1156	1244
Particles >14µm	ASTM D7647	>160	38	68	63
Particles >21µm	ASTM D7647	>40	18	16	19
Particles >38µm	ASTM D7647	>10	3	1	0
Particles >71µm	ASTM D7647	>3	2	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	17/15/12	19/17/13	▲ 20/17/13




OIL ANALYSIS REPORT


Particle Trend




Particle Count



Viscosity @ 40°C



Particle Trend




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		5.81	2.49	1.26

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		29.4	28.1	27.3

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0801015 **Received** : 29 May 2023
Lab Number : 02560183 **Diagnosed** : 30 May 2023
Unique Number : 5581223 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

PETERBOROUGH UTILITIES INC
 1867 ASHBURNHAM DRIVE
 PETERBOROUGH, ON
 CA K9L 1P8
 Contact: Nelson Ross
 nross@pui.ca
 T: (705)760-6119
 F: (705)748-3138

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.