




PROBLEM SUMMARY

Sample Rating Trend



DEGRADATION



Area
[235354/153888]
 Machine Id
HILL PHOENIX RACK B #1538 (S/N 74204-82)
 Component
Reciprocating Compressor
 Fluid
BITZER BSE 85 K (--- LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Please note that this is a corrected copy for data entry updates.

PROBLEMATIC TEST RESULTS

| Sample Status | mg KOH/g | ASTM D974* | 0.02 | SEVERE | --- | --- |
|------------------|----------|------------|------|--------|-----|-----|
| Acid Number (AN) | 0.93 | 0.02 | 0.02 | 0.93 | --- | --- |
| Visc @ 40°C | 66.0 | 80 | 80 | 66.0 | --- | --- |

Customer Id: DISED
 Sample No.: WC0816808
 Lab Number: 02560224
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|--------------|--------|------|---------|---|
| Change Fluid | --- | --- | ? | We recommend that you drain the oil from the component if this has not already been done. |
| Resample | --- | --- | ? | We recommend an early resample to monitor this condition. |

HISTORICAL DIAGNOSIS




OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION

Area
[235354/153888]
 Machine Id
HILL PHOENIX RACK B #1538 (S/N 74204-82)
 Component
Reciprocating Compressor
 Fluid
BITZER BSE 85 K (--- LTR)



DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Please note that this is a corrected copy for data entry updates.

Wear

All component wear rates are normal.

Contamination

The water content is negligible.

Fluid Condition

The oil viscosity is higher than normal. The high AN level of the oil indicates the presence of oxipolymerized products. The AN level is much higher than the recommended limit. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. The oil is no longer serviceable.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-----------------|------------|--------------------|----------|----------|
| Sample Number | Client Info | | WC0816808 | --- | --- |
| Sample Date | Client Info | | 09 May 2023 | --- | --- |
| Machine Age | yrs Client Info | | 10 | --- | --- |
| Oil Age | yrs Client Info | | 0 | --- | --- |
| Oil Changed | Client Info | | N/A | --- | --- |
| Sample Status | | | SEVERE | --- | --- |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|-----------|-------------------|------------|--------------|----------|----------|
| PQ | ASTM D8184* | | 0 | --- | --- |
| Iron | ppm ASTM D5185(m) | >50 | 12 | --- | --- |
| Chromium | ppm ASTM D5185(m) | >10 | 0 | --- | --- |
| Nickel | ppm ASTM D5185(m) | | 0 | --- | --- |
| Titanium | ppm ASTM D5185(m) | | 0 | --- | --- |
| Silver | ppm ASTM D5185(m) | | 0 | --- | --- |
| Aluminum | ppm ASTM D5185(m) | >25 | <1 | --- | --- |
| Lead | ppm ASTM D5185(m) | >25 | 0 | --- | --- |
| Copper | ppm ASTM D5185(m) | >50 | <1 | --- | --- |
| Tin | ppm ASTM D5185(m) | >15 | <1 | --- | --- |
| Antimony | ppm ASTM D5185(m) | | 0 | --- | --- |
| Vanadium | ppm ASTM D5185(m) | | 0 | --- | --- |
| Beryllium | ppm ASTM D5185(m) | | 0 | --- | --- |
| Cadmium | ppm ASTM D5185(m) | | 0 | --- | --- |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|-------------------|------------|--------------|----------|----------|
| Boron | ppm ASTM D5185(m) | 0 | <1 | --- | --- |
| Barium | ppm ASTM D5185(m) | 0 | 0 | --- | --- |
| Molybdenum | ppm ASTM D5185(m) | 0 | 0 | --- | --- |
| Manganese | ppm ASTM D5185(m) | 0 | 0 | --- | --- |
| Magnesium | ppm ASTM D5185(m) | 0 | 0 | --- | --- |
| Calcium | ppm ASTM D5185(m) | 0 | 0 | --- | --- |
| Phosphorus | ppm ASTM D5185(m) | 1200 | 1051 | --- | --- |
| Zinc | ppm ASTM D5185(m) | 0 | 1 | --- | --- |
| Sulfur | ppm ASTM D5185(m) | 0 | 4 | --- | --- |
| Lithium | ppm ASTM D5185(m) | | <1 | --- | --- |

CONTAMINANTS





| | method | limit/base | current | history1 | history2 |
|-----------|-------------------|------------|--------------|----------|----------|
| Silicon | ppm ASTM D5185(m) | >25 | 2 | --- | --- |
| Sodium | ppm ASTM D5185(m) | | <1 | --- | --- |
| Potassium | ppm ASTM D5185(m) | >20 | <1 | --- | --- |
| Water | % ASTM D6304* | >0.1 | 0.037 | --- | --- |
| ppm Water | ppm ASTM D6304* | >1000 | 372.9 | --- | --- |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|---------------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g ASTM D974* | 0.02 | 0.93 | --- | --- |



OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|----------|----------|-----|
| White Metal | scalar | Visual* | NONE | NONE | --- | --- |
| Yellow Metal | scalar | Visual* | NONE | NONE | --- | --- |
| Precipitate | scalar | Visual* | NONE | NONE | --- | --- |
| Silt | scalar | Visual* | NONE | NONE | --- | --- |
| Debris | scalar | Visual* | NONE | NONE | --- | --- |
| Sand/Dirt | scalar | Visual* | NONE | NONE | --- | --- |
| Appearance | scalar | Visual* | NORML | NORML | --- | --- |
| Odor | scalar | Visual* | NORML | FREON | --- | --- |
| Emulsified Water | scalar | Visual* | >0.1 | NEG | --- | --- |
| Free Water | scalar | Visual* | | NEG | --- | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|---------------|-----------|----------|----------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 80 ▲ 66.0 | --- | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

| | | | |
|--------|--|----------|----------|
| Color | | no image | no image |
| Bottom | | no image | no image |

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0816808 **Received** : 29 May 2023
Lab Number : 02560224 **Diagnosed** : 05 Jun 2023
Unique Number : 5581264 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KF, TAN Man)

Display Fixtures - Loblaw's
 14740-111 Avenue
 Edmonton, AB
 CA T5M 2P5
 Contact: Ross Richards
 ross.richards@loblaw.ca
 T: (780)232-2699
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.