




# PROBLEM SUMMARY

Sample Rating Trend



ISO



Area

5

Machine Id

## 5-3-250 Atox Rollers Hyd. Pressure Pump

Component


Hydraulic System

Fluid

ESSO NUTO H ISO 68 (1000 LTR)

### COMPONENT CONDITION SUMMARY

▲ Particle Trend



### RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

### PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	SEVERE
Particles >6µm	ASTM D7647	>5000	▲ 19131	▲ 8005	● 47976
Particles >14µm	ASTM D7647	>640	▲ 893	37	▲ 2175
Oil Cleanliness	ISO 4406 (c)	>--/19/16	▲ 23/21/17	▲ 23/20/12	● 24/23/18

Customer Id: STMBOW

Sample No.: WC0818146

Lab Number: 02560253

Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Kevin Marson +1 (289)291-4644 x4644

[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:

Gloria Gonzalez +1 (289)291-4643 x4643

[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

## HISTORICAL DIAGNOSIS

### 16 Nov 2022 Diag: Kevin Marson

#### WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Iron ppm levels are noted. A sharp increase in the iron level is noted. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. All other component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 28 Jul 2022 Diag: Wes Davis

#### ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >14µm are abnormally high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 11 May 2022 Diag: Wes Davis

#### ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >6µm are abnormally high. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

5

Machine Id

## 5-3-250 Atox Rollers Hyd. Pressure Pump

Component

Hydraulic System

Fluid

ESSO NUTO H ISO 68 (1000 LTR)

### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

#### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0818146</b>	WC0751898	WC0714907
Sample Date	Client Info		<b>18 May 2023</b>	16 Nov 2022	28 Jul 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ATTENTION	SEVERE

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<b>2</b>	▲ 20	12
Chromium	ppm	ASTM D5185(m)	>20	<b>1</b>	8	5
Nickel	ppm	ASTM D5185(m)	>20	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	3	2
Tin	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0.6	<b>0</b>	<1	<1
Barium	ppm	ASTM D5185(m)	0.0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	0.0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	0.0	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	0.0	<b>71</b>	52	50
Calcium	ppm	ASTM D5185(m)	44	<b>12</b>	22	27
Phosphorus	ppm	ASTM D5185(m)	319	<b>321</b>	323	296
Zinc	ppm	ASTM D5185(m)	400	<b>352</b>	345	342
Sulfur	ppm	ASTM D5185(m)	2810	<b>741</b>	2109	2342
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	2
Sodium	ppm	ASTM D5185(m)		<b>0</b>	<1	0
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	<1

### FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>60000</b>	51779	111340
Particles >6µm	ASTM D7647	>5000	▲ <b>19131</b>	▲ 8005	■ 47976
Particles >14µm	ASTM D7647	>640	▲ <b>893</b>	37	▲ 2175
Particles >21µm	ASTM D7647	>160	<b>147</b>	6	220
Particles >38µm	ASTM D7647	>40	<b>1</b>	1	1
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	▲ <b>23/21/17</b>	▲ 23/20/12	■ 24/23/18

### FLUID DEGRADATION


	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.48	<b>0.37</b>	0.39	0.42

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Particle Trend



### Acid Number




### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	66.2	61.5	62.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0818146 **Received** : 29 May 2023  
**Lab Number** : 02560253 **Diagnosed** : 30 May 2023  
**Unique Number** : 5581293 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**ST. MARYS CEMENT CO.**  
 400 BOWMANVILLE AVENUE  
 BOWMANVILLE, ON  
 CA L1C 7B5  
 Contact: Aleksandrs Cascins  
 Alex.Cascins@vcimentos.com  
 T: (905)623-3341  
 F: (905)623-4695