




PROBLEM SUMMARY


Area
6
 Machine Id
6-3-652 Coal Mill Slide Shoe L/P Gear
 Component
Pump
 Fluid
MOBIL MOBILGEAR SHC 460 (300 LTR)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

Particle Trend



Non-ferrous Metals



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

| Sample Status | | | SEVERE | SEVERE | SEVERE | |
|-----------------|-----|---------------|-----------|------------|------------|------------|
| Tin | ppm | ASTM D5185(m) | >9 | ▲ 162 | ● 282 | ● 200 |
| Antimony | ppm | ASTM D5185(m) | | ▲ 24 | ▲ 46 | ▲ 31 |
| Particles >6µm | | ASTM D7647 | >20000 | ● 412665 | ● 434538 | ● 540089 |
| Particles >14µm | | ASTM D7647 | >5000 | ● 95101 | ● 210153 | ● 208620 |
| Particles >21µm | | ASTM D7647 | >1300 | ● 18831 | ● 85953 | ● 77140 |
| Oil Cleanliness | | ISO 4406 (c) | >--/21/19 | ● 26/26/24 | ● 26/26/25 | ● 26/26/25 |

Customer Id: STMBOW
 Sample No.: WC0818167
 Lab Number: 02560352
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|-------------------|--------|------|---------|--|
| Change Filter | --- | --- | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |
| Resample | --- | --- | ? | Resample in 30-45 days to monitor this situation. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). |
| Check Breathers | --- | --- | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. |
| Check Dirt Access | --- | --- | ? | We advise that you check all areas where contaminants can enter the system. |
| Filter Fluid | --- | --- | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |

HISTORICAL DIAGNOSIS

04 Jan 2023 Diag: Kevin Marson

WEAR



We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Resample in 30-45 days to monitor this situation. Tin ppm levels are severe. Antimony ppm levels are abnormal. Bearing and/or bushing wear is indicated. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm and oil cleanliness are severely high. Particles >38µm are abnormally high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



12 Dec 2022 Diag: Kevin Marson

WEAR



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Tin ppm levels are severe. Antimony ppm levels are abnormal. Lead ppm levels are noted. Bearing and/or bushing wear is indicated. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm and oil cleanliness are severely high. Particles >38µm are abnormally high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



27 Nov 2022 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Tin ppm levels are abnormal. Light concentration of visible metal present. Bearing and/or gear wear is indicated. Bearing and/or bushing wear is indicated. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm and oil cleanliness are severely high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

6

Machine Id

6-3-652 Coal Mill Slide Shoe L/P Gear

Component

Pump

Fluid

MOBIL MOBILGEAR SHC 460 (300 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear

Tin and antimony ppm levels are abnormal. Bearing and/or bushing wear is indicated.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

| method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|-------------|-------------|
| Sample Number | Client Info | WC0818167 | WC | WC0754479 |
| Sample Date | Client Info | 15 May 2023 | 04 Jan 2023 | 12 Dec 2022 |
| Machine Age | hrs | Client Info | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 |
| Oil Changed | Client Info | N/A | N/A | N/A |
| Sample Status | | SEVERE | SEVERE | SEVERE |

WEAR METALS

| method | limit/base | current | history1 | history2 | | |
|-----------|------------|---------------|----------|----------|-----|-----|
| Iron | ppm | ASTM D5185(m) | >90 | 9 | 17 | 16 |
| Chromium | ppm | ASTM D5185(m) | >5 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >5 | <1 | <1 | <1 |
| Titanium | ppm | ASTM D5185(m) | >3 | 0 | <1 | 0 |
| Silver | ppm | ASTM D5185(m) | >3 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) | >7 | 1 | 2 | 2 |
| Lead | ppm | ASTM D5185(m) | >12 | 6 | 9 | 8 |
| Copper | ppm | ASTM D5185(m) | >30 | 9 | 17 | 12 |
| Tin | ppm | ASTM D5185(m) | >9 | 162 | 282 | 200 |
| Antimony | ppm | ASTM D5185(m) | | 24 | 46 | 31 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | <1 | <1 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 2 | 3 | 2 |

ADDITIVES

| method | limit/base | current | history1 | history2 | | |
|------------|------------|---------------|----------|----------|------|------|
| Boron | ppm | ASTM D5185(m) | 5.7 | 9 | 13 | 14 |
| Barium | ppm | ASTM D5185(m) | 0.0 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) | 0.0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | 0.0 | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185(m) | 0.0 | 0 | 0 | 0 |
| Calcium | ppm | ASTM D5185(m) | 0.0 | 1 | <1 | 0 |
| Phosphorus | ppm | ASTM D5185(m) | 180 | 437 | 431 | 419 |
| Zinc | ppm | ASTM D5185(m) | 0.8 | 2 | 1 | 2 |
| Sulfur | ppm | ASTM D5185(m) | 4270 | 4484 | 4507 | 4549 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |

CONTAMINANTS






| method | limit/base | current | history1 | history2 | | |
|-----------|------------|---------------|----------|----------|----|----|
| Silicon | ppm | ASTM D5185(m) | >60 | 2 | 3 | 3 |
| Sodium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |

FLUID CLEANLINESS

| method | limit/base | current | history1 | history2 |
|-----------------|--------------|-----------|----------|----------|
| Particles >4µm | ASTM D7647 | 510976 | 482862 | 627183 |
| Particles >6µm | ASTM D7647 | >20000 | 412665 | 434538 |
| Particles >14µm | ASTM D7647 | >5000 | 95101 | 210153 |
| Particles >21µm | ASTM D7647 | >1300 | 18831 | 85953 |
| Particles >38µm | ASTM D7647 | >320 | 36 | 893 |
| Particles >71µm | ASTM D7647 | >80 | 0 | 17 |
| Oil Cleanliness | ISO 4406 (c) | >--/21/19 | 26/26/24 | 26/26/25 |

FLUID DEGRADATION


| method | limit/base | current | history1 | history2 | | |
|------------------|------------|------------|----------|----------|------|------|
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.38 | 0.80 | 0.83 | 0.82 |







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | Visual* | NONE | NONE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | VLITE | NONE |
| Debris | scalar | Visual* | NONE | NONE | VLITE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | NEG | NEG | NEG |
| Free Water | scalar | Visual* | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|---------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 477 | 456 | 463 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0818167 **Received** : 29 May 2023
Lab Number : 02560352 **Diagnosed** : 30 May 2023
Unique Number : 5581392 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

ST. MARYS CEMENT CO.
 400 BOWMANVILLE AVENUE
 BOWMANVILLE, ON
 CA L1C 7B5
 Contact: Lou Traiforos
 lou.traiforos@vcimentos.com
 T: (905)440-5874
 F: (905)623-4695