



PROBLEM SUMMARY

Sample Rating Trend

WEAR




Area

8
Machine Id
8-2-301-C FM #2 Trunion - Discharge End


Component
Journal Bearing

Fluid
MOBIL MOBILGEAR SHC 460 (350 LTR)




COMPONENT CONDITION SUMMARY


Non-ferrous Metals



Particle Trend



Additives



RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ABNORMAL	
Tin	ppm	ASTM D5185(m)	>80	448	348	165
Antimony	ppm	ASTM D5185(m)		40	27	12
Particles >6µm		ASTM D7647	>320000	359452	438164	135297
Oil Cleanliness		ISO 4406 (c)	>--/25/24	26/26/23	26/26/21	25/24/20

Customer Id: STMBOW
Sample No.: WC0818189
Lab Number: 02560375
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

WEAR



16 Nov 2022 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Tin and antimony ppm levels are abnormal. Bearing wear is indicated. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Calcium and/or magnesium levels higher than normal indicating possible contamination with cement dust, advise investigate. Viscosity of sample indicates oil is within SAE 140 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid.

[view report](#)



WEAR



26 Jul 2022 Diag: Kevin Marson

Resample at the next service interval to monitor. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Tin ppm levels are abnormal. Antimony ppm levels are marginal. A sharp increase in the tin level is noted. A sharp increase in the antimony level is noted. Bearing wear is indicated. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



NORMAL



16 May 2022 Diag: Kevin Marson

Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area

8

Machine Id

8-2-301-C FM #2 Trunion - Discharge End

Component

Journal Bearing

Fluid

MOBIL MOBILGEAR SHC 460 (350 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Tin ppm levels are severe. Antimony ppm levels are abnormal. Bearing wear is indicated.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0818189	WC0751942	WC0714976
Sample Date	Client Info		17 May 2023	16 Nov 2022	26 Jul 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>60	44	34	19
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	<1	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>4	2	2	<1
Lead	ppm	ASTM D5185(m)	>250	5	3	2
Copper	ppm	ASTM D5185(m)	>125	19	12	5
Tin	ppm	ASTM D5185(m)	>80	448	348	165
Antimony	ppm	ASTM D5185(m)		40	27	12
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	5.7	9	2	4
Barium	ppm	ASTM D5185(m)	0.0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0.0	0	0	0
Manganese	ppm	ASTM D5185(m)	0.0	<1	<1	<1
Magnesium	ppm	ASTM D5185(m)	0.0	1	3	<1
Calcium	ppm	ASTM D5185(m)	0.0	47	151	19
Phosphorus	ppm	ASTM D5185(m)	180	415	318	306
Zinc	ppm	ASTM D5185(m)	0.8	<1	1	1
Sulfur	ppm	ASTM D5185(m)	4270	4461	2675	2427
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>50	7	6	4
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	2	4	1






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		437896	606769	196563
Particles >6µm	ASTM D7647	>320000	359452	438164	135297
Particles >14µm	ASTM D7647	>160000	63284	19626	6462
Particles >21µm	ASTM D7647	>40000	3702	527	400
Particles >38µm	ASTM D7647	>10000	2	0	1
Particles >71µm	ASTM D7647	>2500	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/25/24	26/26/23	26/26/21	25/24/20

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.38	0.66	0.42	0.71

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	LIGHT	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	477	436	387

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0818189 **Received** : 29 May 2023
Lab Number : 02560375 **Diagnosed** : 30 May 2023
Unique Number : 5581415 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

ST. MARYS CEMENT CO.
 400 BOWMANVILLE AVENUE
 BOWMANVILLE, ON
 CA L1C 7B5
 Contact: Aleksandrs Cascins
 Alex.Cascins@vcimentos.com
 T: (905)623-3341
 F: (905)623-4695

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.