




OIL ANALYSIS REPORT

Sample Rating Trend



CONTAMINANT



Area
PUMPHOUSE/AIR COMPRESSORS
 Machine Id
C - 3 Air Compressor TURBINE Compressor Oil Sump
 Component
Lube System
 Fluid
SULLAIR SULLUBE (45 GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. *** NOTE: There was not enough oil in the system to take a sample! Check the lube oil reservoir. ***

Wear

{not applicable}

Contamination

{not applicable}

Fluid Condition

{not applicable}

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC	WC0785649	WC0772647
Sample Date	Client Info		30 May 2023	27 Jan 2023	14 Dec 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	NORMAL

VISUAL




	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NOOIL	NORML
Odor	scalar	Visual*	NORML	NORML	NORML

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color					
Bottom					

OIL ANALYSIS REPORT

GRAPHS



Laboratory	: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9	STELCO - BOSC - Basic Oxygen Slab Caster
Sample No.	: WC	2330 Regional Road #3, Door: BOSC8
Lab Number	: 02561093	NANTICOKE, ON
Unique Number	: 5590134	CA N0A 1L0
Test Package	: TEST	Contact: Tom Walden

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Thomas.Walden@stelco.com
 T: (519)587-4541
 F: (519)587-7702