




PROBLEM SUMMARY

Sample Rating Trend



WATER




Machine Id
BDE UNIT 6 (S/N Bx00003-006)

Component
Transformer Oil

Fluid
ENVIROTEMP FR3 FLUID (1620 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	---
Water	%	ASTM D6304*	>0.02	▲ 0.036	0.013	---
ppm Water	ppm	ASTM D6304*	>200	▲ 366.3	0	---

Customer Id: NEWMIL
Sample No.: WC0502015
Lab Number: 02562003
Test Package: TRF 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Bill Quesnel CLS, OMA II, MLA-III, LLA-I +1
(289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the transformer oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.

HISTORICAL DIAGNOSIS

21 May 2020 Diag: Bill Quesnel

DEGRADATION



We recommend that you drain the transformer oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The interfacial tension (IFT) for this fluid is very low. The transformer oil is no longer serviceable.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
BDE UNIT 6 (S/N Bx00003-006)

Component
Transformer Oil

Fluid
ENVIROTEMP FR3 FLUID (1620 GAL)

DIAGNOSIS

▲ Recommendation

We recommend an early resample to monitor this condition.

Wear

{not applicable}

▲ Contamination

There is a moderate concentration of water present in the transformer oil. The system cleanliness is acceptable for your target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The transformer oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0502015	WC0380025	---
Sample Date	Client Info	23 Aug 2021	21 May 2020	---
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	---
Sample Status		ABNORMAL	SEVERE	---

CONTAMINANTS

method	limit/base	current	history1	history2
Water	%	ASTM D6304* >0.02	▲ 0.036	0.013
ppm Water	ppm	ASTM D6304* >200	▲ 366.3	0

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	1988	3019
Particles >6µm	ASTM D7647	>1300	597	1008
Particles >14µm	ASTM D7647	>160	53	122
Particles >21µm	ASTM D7647	>40	14	50
Particles >38µm	ASTM D7647	>10	1	3
Particles >71µm	ASTM D7647	>3	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	18/16/13	19/17/14

DISSOLVED GAS ANALYSIS (DGA)

method	limit/base	current	history1	history2
DGA - H2	ppm	ASTM D3612(e)*	6	---
DGA - O2	ppm	ASTM D3612(e)*	247	---
DGA - N2	ppm	ASTM D3612(e)*	60797	---
DGA - CO	ppm	ASTM D3612(e)*	33	---
DGA - CO2	ppm	ASTM D3612(e)*	390	---
DGA - Methane	ppm	ASTM D3612(e)*	2	---
DGA - Acetylene	ppm	ASTM D3612(e)*	0	---
DGA - Ethylene	ppm	ASTM D3612(e)*	2	---
DGA - Ethane	ppm	ASTM D3612(e)*	193	---
DGA - Total Gas Content	%	ASTM D3612(e)*	61670	---
DGA - Total Combustible Gas	ppm	ASTM D3612(e)*	236	---

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.22	0.07	0.05

VISUAL

method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE
Silt	scalar	Visual*	NONE	NONE
Debris	scalar	Visual*	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML
Odor	scalar	Visual*	NORML	NORML




OIL ANALYSIS REPORT









FLUID PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D4052(e)	0.92	0.921	0.923	---
Dielectric Breakdown	kV	ASTM D3612(e)*		51	44	---
Interfacial Tension	mN/m	ASTM D971(e)*		15.01	14.83	---
ASTM Color	scalar	ASTM D1500(e)		L0.5	>0.5	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 NEWFOUNDLAND & LABRADOR HYDRO
Sample No. : WC0502015 **Received** : 05 Jun 2023 BAY D'ESPOIR WHSE., 1 CAMP BOGGY RD., PO BOX 100
Lab Number : **02562003** **Diagnosed** : 27 Jul 2023 MILLTOWN, BAY D'ESPOIR, NL
Unique Number : 5591044 **Diagnostician** : Bill Quesnel CA A0H 1W0
Test Package : TRF 2 (Additional Tests: PrtCount)
 Contact: Matthew Lambert
 matthewlambert@nlh.nl.ca
 T: (709)882-3126
 F: (709)882-3161

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.