




PROBLEM SUMMARY

Sample Rating Trend



WEAR




Area
[199036]
Machine Id
HCP G1 TUBR


Component
Turbine
Fluid
MOBIL DTE OIL HVY MEDIUM (27 LTR)

COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	SEVERE	SEVERE
Copper	ppm	ASTM D5185(m) >5	▲ 21	● 35	● 48
Particles >6µm		ASTM D7647 >640	▲ 3588	▲ 3843	● 18464
Oil Cleanliness		ISO 4406 (c) >--/16/13	▲ 22/19/13	▲ 21/19/15	● 23/21/17

Customer Id: NEWSTJ
Sample No.: WC0455583
Lab Number: 02563216
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

27 May 2022 Diag: Kevin Marson

WEAR



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Copper ppm levels are severe. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >6µm and oil cleanliness are abnormally high. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



WEAR



21 Oct 2021 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Copper ppm levels are severe. Lead ppm levels are abnormal. A sharp increase in the copper level is noted. An increase in the lead level is noted. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Particles >38µm are abnormally high. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



WATER



27 Feb 2020 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you change the oil. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Water Water and ppm water contamination levels are severe. Particles >6µm are severely high. Particles >6µm are severely high.. Particles >14µm are abnormally high. Particles >21µm are notably high. There is a high concentration of water present in the oil. Free water present. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The white residue present in the sample is oil additive precipitate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
[199036]
 Machine Id
HCP G1 TUBR
 Component
Turbine
 Fluid
MOBIL DTE OIL HVY MEDIUM (27 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

Copper ppm levels are abnormal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0455583	WC0445386	WC0445210
Sample Date	Client Info		04 May 2023	27 May 2022	21 Oct 2021
Machine Age	hrs	Client Info	80	80	0
Oil Age	hrs	Client Info	80	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >15	2	1	1
Chromium	ppm	ASTM D5185(m) >4	0	0	0
Nickel	ppm	ASTM D5185(m) >2	0	0	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	<1	<1
Aluminum	ppm	ASTM D5185(m) >10	<1	0	<1
Lead	ppm	ASTM D5185(m)	18	18	▲ 24
Copper	ppm	ASTM D5185(m) >5	▲ 21	● 35	● 48
Tin	ppm	ASTM D5185(m) >5	0	0	0
Antimony	ppm	ASTM D5185(m)	<1	<1	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	0	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	0
Calcium	ppm	ASTM D5185(m)	0	0	<1
Phosphorus	ppm	ASTM D5185(m)	138	134	129
Zinc	ppm	ASTM D5185(m)	42	40	35
Sulfur	ppm	ASTM D5185(m)	1623	649	1821
Lithium	ppm	ASTM D5185(m)	<1	<1	<1


CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	1	<1	2
Sodium	ppm	ASTM D5185(m)	<1	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1
Water	%	ASTM D6304* >0.03	0.026	0.001	0.001
ppm Water	ppm	ASTM D6304* >300	260.9	14.1	14.3


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		22347	17409	74063
Particles >6µm	ASTM D7647	>640	▲ 3588	▲ 3843	● 18464
Particles >14µm	ASTM D7647	>80	50	▲ 231	● 1126
Particles >21µm	ASTM D7647	>20	10	▲ 61	● 267
Particles >38µm	ASTM D7647	>4	1	2	▲ 15
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/16/13	▲ 22/19/13	▲ 21/19/15	● 23/21/17


Particle Trend




Water (KF)




Non-ferrous Metals



Acid Number



Water (KF)




FLUID DEGRADATION

method	limit/base	current	history1	history2		
Acid Number (AN) mg KOH/g	ASTM D974*	0.05	0.08	0.04		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.03	.2%	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES


method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D7279(m)	65.0	67.3	65.6

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
 Sample No. : WC0455583
 Lab Number : **02563216**
 Unique Number : 5592257
 Test Package : IND 2

Received : 09 Jun 2023
 Diagnosed : 12 Jun 2023
 Diagnostician : Kevin Marson

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
 F: (709)737-2926