




# PROBLEM SUMMARY

Sample Rating Trend




ISO




Area  
**F1**  
 Machine Id  
**ATLAS COPCO 1025085 Compressor (2) (S/N AP1313658)**  
 Component  
**Oil**  
 Fluid  
**ATLAS COPCO ROTO XTEND (8 LTR)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



Additives



## RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	NORMAL	NORMAL
Particles >4µm	ASTM D7647 >10000	▲ 16724	---	---
Particles >6µm	ASTM D7647 >2500	▲ 3773	---	---
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 21/19/15	---	---

Customer Id: WATGEO  
 Sample No.: WC0651215  
 Lab Number: 02564079  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.
Other Action (see Note)	DONE	Jul 25 2023	?	No recommended actions

## HISTORICAL DIAGNOSIS

### 31 May 2022 Diag: Kevin Marson

NORMAL



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Jun 2021 Diag: Kevin Marson

NORMAL



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 28 Aug 2020 Diag: Kevin Marson

ADDITIVES



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





# OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Area

F1

Machine Id


ATLAS COPCO 1025085 Compressor (2) (S/N AP1313658)

Component

Oil

Fluid

ATLAS COPCO ROTO XTEND (8 LTR)



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0651215	WC0651222	WC0506364
Sample Date	Client Info		12 Jun 2023	31 May 2022	21 Jun 2021
Machine Age	Client Info		25278	26632	25965
Oil Age	Client Info		1906	3263	2596
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			ATTENTION	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	0
Iron	ppm ASTM D5185(m)	>10	<1	<1	<1
Chromium	ppm ASTM D5185(m)		0	0	0
Nickel	ppm ASTM D5185(m)		0	<1	<1
Titanium	ppm ASTM D5185(m)		0	0	0
Silver	ppm ASTM D5185(m)		0	0	<1
Aluminum	ppm ASTM D5185(m)		1	1	<1
Lead	ppm ASTM D5185(m)		0	0	0
Copper	ppm ASTM D5185(m)	>10	<1	<1	<1
Tin	ppm ASTM D5185(m)		0	0	0
Antimony	ppm ASTM D5185(m)		0	<1	0
Vanadium	ppm ASTM D5185(m)		0	0	0
Beryllium	ppm ASTM D5185(m)		0	0	0
Cadmium	ppm ASTM D5185(m)		0	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)		<1	<1	<1
Barium	ppm ASTM D5185(m)		<1	<1	<1
Molybdenum	ppm ASTM D5185(m)		0	0	0
Manganese	ppm ASTM D5185(m)		<1	<1	<1
Magnesium	ppm ASTM D5185(m)		1	2	2
Calcium	ppm ASTM D5185(m)		13	22	24
Phosphorus	ppm ASTM D5185(m)		123	130	121
Zinc	ppm ASTM D5185(m)		120	113	101
Sulfur	ppm ASTM D5185(m)		274	285	294
Lithium	ppm ASTM D5185(m)		<1	<1	<1

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m)	>30	1	0	<1
Sodium	ppm ASTM D5185(m)		6	5	6
Potassium	ppm ASTM D5185(m)	>20	0	<1	<1
Water	% ASTM D6304*	>0.1	0.001	0.001	---
ppm Water	ppm ASTM D6304*	>1000	7.7	10.4	---

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 16724	---	---
Particles >6µm	ASTM D7647	>2500	▲ 3773	---	---
Particles >14µm	ASTM D7647	>320	198	---	---
Particles >21µm	ASTM D7647	>80	41	---	---
Particles >38µm	ASTM D7647	>20	1	---	---
Particles >71µm	ASTM D7647	>4	0	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 21/19/15	---	---



# OIL ANALYSIS REPORT








FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.14	<b>0.25</b>	0.20	0.26

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	<b>49.4</b>	48.5	48.4

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Watch Tower Bible and Tract Society of Canada  
**Sample No.** : WC0651215 **Received** : 14 Jun 2023 13893 Highway 7  
**Lab Number** : **02564079** **Diagnosed** : 15 Jun 2023 Georgetown, ON  
**Unique Number** : 5593120 **Diagnostician** : Kevin Marson CA L7G 4S4  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PRTCOUNT, TAN Man )  
 Contact: Purchasing Department  
 purchase.ca@jw.org  
 T: (905)873-4101  
 F: (905)873-4508

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.