




# PROBLEM SUMMARY

Sample Rating Trend




WEAR



Area  
**ENGINE ROOM 3RD DECK**  
 Machine Id  
**27-K-6410A MAIN AIR COMPRESSOR A (S/N Maint Plan 22465)**  
 Component  
**1 Air Compressor**  
 Fluid  
**MOBIL RARUS 826 (4 LTR)**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	ABNORMAL
Iron	ppm	ASTM D5185(m)	>50	188	163	107
Aluminum	ppm	ASTM D5185(m)	>10	104	87	38
Copper	ppm	ASTM D5185(m)	>40	72	58	27
Tin	ppm	ASTM D5185(m)	>5	7	6	2

Customer Id: SPESTJ  
 Sample No.: PP  
 Lab Number: 02564369  
 Test Package: IND 1



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 24 Apr 2023 Diag: Kevin Marson

#### WEAR



We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Aluminum and iron ppm levels are severe. Tin and copper ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated. Bearing wear is indicated. Piston wear is indicated. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. There is no indication of any contamination in the oil. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



### 15 Nov 2022 Diag: Kevin Marson

#### WEAR



We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Aluminum and iron ppm levels are abnormal. Copper ppm levels are noted. Oil cooler core leaching or motor piston wear is indicated. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. There is no indication of any contamination in the oil. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



### 29 Aug 2022 Diag: Wes Davis

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area  
**ENGINE ROOM 3RD DECK**  
 Machine Id  
**27-K-6410A MAIN AIR COMPRESSOR A (S/N Maint Plan 22465)**  
 Component  
**1 Air Compressor**  
 Fluid  
**MOBIL RARUS 826 (4 LTR)**

## DIAGNOSIS

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PP</b>	PP	PP
Sample Date	Client Info			<b>22 May 2023</b>	24 Apr 2023	15 Nov 2022
Machine Age	days	Client Info		<b>0</b>	0	0
Oil Age	days	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>SEVERE</b>	SEVERE	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		<b>52</b>	27	23
Iron	ppm	ASTM D5185(m)	>50	<b>188</b>	163	107
Chromium	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185(m)	>4	<b>1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>10	<b>104</b>	87	38
Lead	ppm	ASTM D5185(m)	>20	<b>2</b>	1	<1
Copper	ppm	ASTM D5185(m)	>40	<b>72</b>	58	27
Tin	ppm	ASTM D5185(m)	>5	<b>7</b>	6	2
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<b>2</b>	2	3
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>8</b>	6	3
Manganese	ppm	ASTM D5185(m)		<b>2</b>	2	1
Magnesium	ppm	ASTM D5185(m)		<b>1</b>	<1	0
Calcium	ppm	ASTM D5185(m)		<b>9</b>	2	2
Phosphorus	ppm	ASTM D5185(m)		<b>118</b>	120	116
Zinc	ppm	ASTM D5185(m)		<b>30</b>	27	19
Sulfur	ppm	ASTM D5185(m)		<b>122</b>	104	123
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	<b>18</b>	16	8
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.6	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG




# OIL ANALYSIS REPORT


## Aluminum (ppm)




## Aluminum (ppm)




## Non-ferrous Metals



## Viscosity @ 40°C



## PQ



## FLUID PROPERTIES


method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m) 66.5	65.7	66.0	65.8

## SAMPLE IMAGES


method	limit/base	current	history1	history2
Color				
Bottom				

## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals



### Viscosity @ 40°C



### PQ



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory Sample No.**

**Lab Number**

**Unique Number**

**Test Package**

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS

: PP **Received** : 15 Jun 2023

: 02564369 **Diagnosed** : 15 Jun 2023

: 5593410 **Diagnostician** : Kevin Marson

: IND 1 ( Additional Tests: PQ )

PO BOX 20

ST. JOHN'S, NL

CA A1C 6C9

Contact: Maintenance Supervisor

maintsuper.searose@huskyenergy.ca

T: x:

F: x:

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.