




PROBLEM SUMMARY

Sample Rating Trend


ISO



Area
(ZONE3) BRUCE B/0B/75120
 Machine Id
0B-75120-CP4-Lube Oil Level
 Component
Bulk Fluid Tank
 Fluid
MOBIL SHC RARUS 68 (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where dirt can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	ABNORMAL
Iron	ppm	ASTM D5185(m)	>10	▲ 19	17	6
Ferrous Rubbing	Scale 0-10	ASTM D7684*		▲ 7	4	3
Phosphorus	ppm	ASTM D5185(m)		● 273	262	76
Silicon	ppm	ASTM D5185(m)	>5	▲ 19	27	8
Particles >4µm		ASTM D7647	>5000	● 216501	71473	44552
Particles >6µm		ASTM D7647	>1300	● 16952	4015	3912
Particles >14µm		ASTM D7647	>320	▲ 332	33	214
Particles >21µm		ASTM D7647	>80	▲ 127	5	60
Oil Cleanliness		ISO 4406 (c)	>19/17/15	● 25/21/16	23/19/12	23/19/15

Customer Id: BRUTIV
 Sample No.: WC0744565
 Lab Number: 02565313
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where dirt can enter the system.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

ISO



09 Apr 2022 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. The fluid was specified as ESSO COMPRESSOR OIL 68, however, a fluid match indicates that this fluid is ISO 68 Synthetic (PAG) Fire-Resistant Fluid. Please confirm the oil type and grade on your next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. Particles >4µm are severely high. Particles >6µm are abnormally high. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ADDITIVES



19 Oct 2012 Diag: Bill Quesnel

The filter change at the time of sampling has been noted. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. Particles >6µm are abnormally high. Particles >14µm and particles >21µm are notably high. The water content is negligible. Additive levels indicate the addition of a different brand, or type of oil. The TAN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ADDITIVES



18 Oct 2012 Diag: Bill Quesnel

The filter change at the time of sampling has been noted. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. Particles >6µm are abnormally high. Particles >14µm and particles >21µm are notably high. The water content is negligible. Additive levels indicate the addition of a different brand, or type of oil. The TAN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
(ZONE3) BRUCE B/0B/75120
Machine Id
0B-75120-CP4-Lube Oil Level
Component
Bulk Fluid Tank
Fluid
MOBIL SHC RARUS 68 (--- GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where dirt can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

Wear

Iron ppm levels are abnormal. Wear particle analysis indicates that the ferrous rubbing particles are abnormal. The diagnosis reflects updated information on this component.

Contaminants

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of dirt present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. High amount of ingressed dirt has caused abrasive wear to the component.

Oil Condition

Phosphorus ppm levels are severely high. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0744565	WC0638217	WC22097303
Sample Date	Client Info		14 Jun 2023	09 Apr 2022	19 Oct 2012
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	Changed
Sample Status			SEVERE	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		1	---	---
Iron	ppm	ASTM D5185(m) >10	▲ 19	17	6
Chromium	ppm	ASTM D5185(m) >5	<1	<1	0
Nickel	ppm	ASTM D5185(m) >5	<1	0	0
Titanium	ppm	ASTM D5185(m) >5	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >5	5	2	<1
Lead	ppm	ASTM D5185(m) >5	<1	0	0
Copper	ppm	ASTM D5185(m) >5	<1	<1	<1
Tin	ppm	ASTM D5185(m) >5	0	<1	<1
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	0
Barium	ppm	ASTM D5185(m)	0	0	<1
Molybdenum	ppm	ASTM D5185(m)	<1	0	0
Manganese	ppm	ASTM D5185(m)	1	<1	<1
Magnesium	ppm	ASTM D5185(m)	0	0	0
Calcium	ppm	ASTM D5185(m)	1	▲ <1	▲ 1
Phosphorus	ppm	ASTM D5185(m)	273	262	76
Zinc	ppm	ASTM D5185(m)	2	▲ 3	▲ 6
Sulfur	ppm	ASTM D5185(m)	243	▲ 291	1690
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >5	▲ 19	27	8
Sodium	ppm	ASTM D5185(m) >5	0	0	2
Potassium	ppm	ASTM D5185(m) >20	<1	0	0
Water	%	ASTM D6304* >0.005	0.003	0.001	0.001
ppm Water	ppm	ASTM D6304* >50	25.3	4.5	10.0

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	216501	71473	44552
Particles >6µm	ASTM D7647	>1300	16952	▲ 4015	▲ 3912
Particles >14µm	ASTM D7647	>320	▲ 332	33	▲ 214
Particles >21µm	ASTM D7647	>80	▲ 127	5	▲ 60
Particles >38µm	ASTM D7647	>20	9	0	4
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/15	25/21/16	23/19/12	▲ 23/19/15



OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	0.52	0.20

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	VLITE	NONE	VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.005	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	65.3	66.5	67.3	66.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0744565
Lab Number : **02565313**
Unique Number : 5594354
Test Package : IND 2 (Additional Tests: A-FERR, BottomAnalysis, DR-FERR, FILTERPATCH, PQ, TAN Man)

Bruce Power - Bruce A PdM
 P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615
 Tiverton, ON
 CA N0G 2T0
 Contact: Pierre Adouki
 pierre.adouki@brucepower.com
 T: (519)361-2673
 F:




To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.



FERROGRAPHY REPORT



Area
(ZONE3) BRUCE B/0B/75120
 Machine Id
0B-75120-CP4-Lube Oil Level
 Component
Bulk Fluid Tank
 Fluid
MOBIL SHC RARUS 68 (--- GAL)




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		27.7	76.6	68.2
Small Particles		DR-Ferr*		17.5	48.3	32.4
Total Particles		DR-Ferr*	>---	45.2	124.9	100.6
Large Particles Percentage	%	DR-Ferr*		22.6	22.7	35.6
Severity Index		DR-Ferr*		283	2168	2442

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		7	4	3
Ferrous Sliding	Scale 0-10	ASTM D7684*				1
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		4	2	1
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*				3
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*		2	1	2
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				1
Sand/Dirt	Scale 0-10	ASTM D7684*		1	1	3
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		2	2	

WEAR

Iron ppm levels are abnormal. Wear particle analysis indicates that the ferrous rubbing particles are abnormal. The diagnosis reflects updated information on this component.

DR Ferrography



This page left intentionally blank