


PROBLEM SUMMARY

BOF/DESULF D Desulph Skimmer West


Hydraulic System


FORSYTHE NO FIRE WG 200R (130 GAL)





COMPONENT CONDITION SUMMARY





RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL				
Sulfur	ppm	ASTM D5185(m)		<u> </u>	19	6				
Potassium	ppm	ASTM D5185(m)	>20	<u>^</u> 2	34	26				
Particles >4µm		ASTM D7647	>5000	<u> </u>	<u>▲</u> 33162	<u>▲</u> 38295				
Particles >6µm		ASTM D7647	>1300	4917	<u></u> 7128	<u>▲</u> 8730				
Particles >14µm		ASTM D7647	>160	<u>448</u>	△ 314	<u>401</u>				
Particles >21µm		ASTM D7647	>40	<u> </u>	▲ 81	△ 97				
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>22/19/16</u>	<u>22/20/15</u>	<u>^</u> 22/20/16				

Customer Id: LEWBOSC Sample No.: WC0832567 Lab Number: 02565792 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS Action **Status** Date Done By Description We advise that you perform a filter service, and use off-line filtration to Change Filter ? improve the cleanliness of the system fluid. Resample ? We recommend an early resample to monitor this condition. ? Check Fluid Source Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

VICUAL METAL

Filter Fluid

30 May 2023 Diag: Kevin Marson

We advise that you check for visible metal particles in the oil. We advise that you add water to increase the water concentration level to 41%. Ensure that only distilled water or boiler feed water condensate are used for make-up. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Light concentration of visible metal present. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water concentration level is lower than acceptable for this fluid. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

?



We advise that you perform a filter service, and use off-line filtration to

improve the cleanliness of the system fluid.

28 Feb 2023 Diag: Kevin Marson



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >14 μ m are abnormally high. Particles >21 μ m are abnormally high. Particles >6 μ m are abnormally high. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



24 Jan 2023 Diag: Kevin Marson



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >4 μ m are abnormally high. Particles >6 μ m are abnormally high. Particles >14 μ m are notably high. Particles >21 μ m are notably high. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.






OIL ANALYSIS REPORT

BOF/DESULF **D** Desulph Skimmer West

Hydraulic System

FORSYTHE NO FIRE WG 200R (130 GAL)



Sample Rating Trend



DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil.

▲ Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid.

		· ·				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0832567	WC0824343	WC0796828
Sample Date		Client Info		20 Jun 2023	30 May 2023	28 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*	>99999	0	7	0
Iron	ppm	ASTM D5185(m)	>20	0	2	<1
Chromium	ppm	ASTM D5185(m)	>20	0	1	<1
Nickel	ppm	ASTM D5185(m)	>20	2	<1	0
Titanium	ppm	ASTM D5185(m)		2	0	0
Silver	ppm	ASTM D5185(m)		<1	<1	0
Aluminum	ppm	ASTM D5185(m)	>20	1	0	0
Lead	ppm	ASTM D5185(m)	>20	1	0	0
Copper	ppm	ASTM D5185(m)	>20	0	3	2
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		<1	0	0
Vanadium	ppm	ASTM D5185(m)		2	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		1	<1	0
ADDITIVES		method	limit/base	current	history1	history2
			III III Dasc			
Boron	ppm	ASTM D5185(m)		2	3	0
Barium	ppm	ASTM D5185(m)		0	<1	0
Molybdenum	ppm	ASTM D5185(m)		2	<1	<1
Manganese	ppm	ASTM D5185(m)		<1 0	0	0
Magnesium	ppm	ASTM D5185(m)		0	1	<1
Calcium	ppm	ASTM D5185(m)		_	3	<1
Phosphorus	ppm	ASTM D5185(m)		<1 0	ە <1	0
Zinc Sulfur	ppm	ASTM D5185(m)			19	<1
Lithium	ppm	ASTM D5185(m) ASTM D5185(m)		▲ 141 <1	<1	6 <1
	ppm			<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0	4	<1
Sodium	ppm	ASTM D5185(m)		188	243	218
Potassium	ppm	ASTM D5185(m)	>20	<u>^</u> 2	34	26
Water	%	ASTM D6304*		37.3	36.9	36.94
ppm Water	ppm	ASTM D6304*	>10%	373000	369000	369498.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	20736	▲ 33162	▲ 38295
Particles >6µm		ASTM D7647		<u>▲</u> 4917	<u>^</u> 7128	▲ 8730
Particles >14µm		ASTM D7647	>160	<u>▲</u> 448	<u> </u>	▲ 401
Particles >21µm		ASTM D7647	>40	<u> </u>	<u></u> ▲ 81	<u></u> 497
Particles >38µm		ASTM D7647	>10	12	6	5
Particles >71µm		ASTM D7647	>3	2	0	0

Submitted By: Bob Melanson



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited

Laboratory Sample No. Lab Number **Unique Number**

: 5594833

: WC0832567 : 02565792

Received Diagnosed

Test Package : IND 2 (Additional Tests: KF, pH, PQ, ReserveAlk, TAN Man)

: 23 Jun 2023 Diagnostician : Kevin Marson

: 21 Jun 2023

2330 Regional Road #3, Door: BOSC8 NANTICOKE, ON

> Contact: Tom Walden Thomas.Walden@stelco.com T: (519)587-4541

F: (519)587-7702

CA NOA 1L0

history2

history2

NONE

NONE

NONE

NONE

NONE

NONE

FRGLY

NORML

history2

history2

no image

>10%

NEG

9.54

43.9

3.74

210