




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
PSI M0003

Component
Diesel Engine

Fluid
DIESEL ENGINE OIL SAE 10W30 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0836806	WC0582015	WC0442716
Sample Date	Client Info		31 Jul 2023	30 Aug 2021	25 Aug 2020
Machine Age	hrs	Client Info	50	36	30
Oil Age	hrs	Client Info	8	15	10
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >100	6	9	8
Chromium	ppm	ASTM D5185(m) >20	0	0	<1
Nickel	ppm	ASTM D5185(m) >4	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	<1
Silver	ppm	ASTM D5185(m) >3	0	0	0
Aluminum	ppm	ASTM D5185(m) >20	1	<1	1
Lead	ppm	ASTM D5185(m) >40	2	4	3
Copper	ppm	ASTM D5185(m) >330	7	14	13
Tin	ppm	ASTM D5185(m) >15	<1	1	<1
Antimony	ppm	ASTM D5185(m)	0	0	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 250	4	6	6
Barium	ppm	ASTM D5185(m) 10	<1	<1	<1
Molybdenum	ppm	ASTM D5185(m) 100	21	52	52
Manganese	ppm	ASTM D5185(m)	<1	<1	<1
Magnesium	ppm	ASTM D5185(m) 450	278	743	726
Calcium	ppm	ASTM D5185(m) 3000	1840	1281	1294
Phosphorus	ppm	ASTM D5185(m) 1150	906	931	915
Zinc	ppm	ASTM D5185(m) 1350	1001	1042	1063
Sulfur	ppm	ASTM D5185(m) 4250	2872	2607	2656
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	21	30	26
Sodium	ppm	ASTM D5185(m)	4	6	5
Potassium	ppm	ASTM D5185(m) >20	1	<1	<1

INFRA-RED


	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844* >3	0	0	0
Nitration	Abs/cm	ASTM D7624* >20	6.0	6.0	5.4
Sulfation	Abs/.1mm	ASTM D7415* >30	17.0	19.1	17.9

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414* >25	10.8	14.3	13.7











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	10.9	11.4	10.6

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0836806 **Received** : 10 Aug 2023
Lab Number : 02575059 **Diagnosed** : 10 Aug 2023
Unique Number : 5620110 **Diagnostician** : Wes Davis
Test Package : MOB 1

GENCARE SERVICES LTD.
 360 SOVEREIGN ROAD
 LONDON, ON
 CA N6M 1A8
 Contact: Teresa Matthews
 tmatthews@gencare.com
 T: (519)659-7118
 F: (519)451-1707

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.