




PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
BOF/OG SYSTEM
 Machine Id
D - O.G. Fan Lube System # 8
 Component
Lube System
 Fluid
PETRO CANADA HYDREX AW 100 (135 GAL)



COMPONENT CONDITION SUMMARY

Particle Trend



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	48216	19957	27048
Particles >6µm	ASTM D7647	>1300	15529	1711	6124
Particles >14µm	ASTM D7647	>160	1274	38	494
Particles >21µm	ASTM D7647	>40	329	12	123
Oil Cleanliness	ISO 4406 (c)	>19/17/14	23/21/17	21/18/12	22/20/16

Customer Id: LEWBOSC
 Sample No.: WC0850092
 Lab Number: 02576221
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

20 Jun 2023 Diag: Kevin Marson

WATER



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Free water present. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



30 May 2023 Diag: Bill Quesnel

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The viscosity of the oil is lower than normal, possibly indicating the addition of a lighter grade of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



28 Feb 2023 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >4µm are severely high.. Particles >4µm are severely high... Particles >38µm are abnormally high. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
BOF/OG SYSTEM
 Machine Id
D - O.G. Fan Lube System # 8
 Component
Lube System
 Fluid
PETRO CANADA HYDREX AW 100 (135 GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0850092	WC0832563	WC0824346
Sample Date	Client Info		16 Aug 2023	20 Jun 2023	30 May 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184*	>99999	0	0	0	
Iron	ppm	ASTM D5185(m)	>20	4	1	<1
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	0	0
Lead	ppm	ASTM D5185(m)	>20	0	5	0
Copper	ppm	ASTM D5185(m)	>20	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<1	<1	0
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	0	0
Calcium	ppm	ASTM D5185(m)	50	49	49	48
Phosphorus	ppm	ASTM D5185(m)	330	353	359	356
Zinc	ppm	ASTM D5185(m)	430	433	424	411
Sulfur	ppm	ASTM D5185(m)	760	2799	2932	2881
Lithium	ppm	ASTM D5185(m)		<1	<1	<1


CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	5	4	3
Sodium	ppm	ASTM D5185(m)		<1	0	0
Potassium	ppm	ASTM D5185(m)	>20	0	0	0


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	48216	19957	27048
Particles >6µm	ASTM D7647	>1300	15529	1711	6124
Particles >14µm	ASTM D7647	>160	1274	38	494
Particles >21µm	ASTM D7647	>40	329	12	123
Particles >38µm	ASTM D7647	>10	7	2	3
Particles >71µm	ASTM D7647	>3	1	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	23/21/17	21/18/12	22/20/16


Particle Trend




PQ




Acid Number



Viscosity @ 40°C



PQ




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	0.52	0.57	0.49

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	VLITE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	.2%	.2%
Free Water	scalar	Visual*		NEG	▲ 1%	NEG


FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	101	92.3	88.0	85.6

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory

Sample No. : WC0850092

Lab Number : 02576221

Unique Number : 5629281

Test Package : IND 2 (Additional Tests: PQ, TAN Man)

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 STELCO - BOSC - Basic Oxygen Slab Caster

Received : 16 Aug 2023

Diagnosed : 18 Aug 2023

Diagnostician : Kevin Marson

2330 Regional Road #3, Door: BOSC8

NANTICOKE, ON

CA N0A 1L0

Contact: Tom Walden

Thomas.Walden@stelco.com

T: (519)587-4541

F: (519)587-7702