




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[9302453238]
 Machine Id
555-12301-1
 Component
Gearbox
 Fluid
ESSO SPARTAN EP 220 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.
 NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0839715	WC0723165	---
Sample Date	Client Info		15 Aug 2023	27 Feb 2023	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			NORMAL	NORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	---
Iron	ppm	ASTM D5185(m) >200	6	6	---
Chromium	ppm	ASTM D5185(m) >15	1	<1	---
Nickel	ppm	ASTM D5185(m) >15	<1	<1	---
Titanium	ppm	ASTM D5185(m)	0	0	---
Silver	ppm	ASTM D5185(m)	0	0	---
Aluminum	ppm	ASTM D5185(m) >25	<1	<1	---
Lead	ppm	ASTM D5185(m) >100	<1	<1	---
Copper	ppm	ASTM D5185(m) >200	<1	<1	---
Tin	ppm	ASTM D5185(m) >25	0	0	---
Antimony	ppm	ASTM D5185(m) >5	0	<1	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) .5	1	2	---
Barium	ppm	ASTM D5185(m)	0	0	---
Molybdenum	ppm	ASTM D5185(m) 0	0	0	---
Manganese	ppm	ASTM D5185(m)	<1	<1	---
Magnesium	ppm	ASTM D5185(m) 0	<1	<1	---
Calcium	ppm	ASTM D5185(m) 1.7	22	21	---
Phosphorus	ppm	ASTM D5185(m) 250	254	261	---
Zinc	ppm	ASTM D5185(m) .3	12	8	---
Sulfur	ppm	ASTM D5185(m)	8574	9155	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	3	3	---
Sodium	ppm	ASTM D5185(m)	2	2	---
Potassium	ppm	ASTM D5185(m) >20	<1	1	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.75	0.63	0.69	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.2	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	220	229	230

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0839715 **Received** : 16 Aug 2023
Lab Number : **02576265** **Diagnosed** : 17 Aug 2023
Unique Number : 5629325 **Diagnostician** : Wes Davis
Test Package : IND 2

DXP - SCS - Sabic IP Cobourg
 44 Normar Road
 Cobourg, ON
 CA K9A 4L7
 Contact: George DiFrancesco
 george.difrancesco@sabic.com
 T: (905)373-3988
 F: (905)373-3844

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.