




# PROBLEM SUMMARY

Sample Rating Trend

**WATER**




Area  
**Caster/Basement**  
 Machine Id  
**Cooper Airmist Compressor #3**  
 Component  
**Air Compressor**  
 Fluid  
**PETRO CANADA HYDREX AW 46 (90 GAL)**




## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



### Additives



## RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	▲ <b>11387</b>	9075	6354
Particles >6µm	ASTM D7647	>2500	▲ <b>2963</b>	1494	1523
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ <b>21/19/15</b>	20/18/12	20/18/14
Appearance	scalar	Visual*	▲ <b>WGOIL</b>	NORML	NORML
Free Water	scalar	Visual*	▲ <b>1%</b>	NEG	NEG

Customer Id: LEWBOSC  
 Sample No.: WC0850098  
 Lab Number: 02576269  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.
Check Water Access	---	---	?	We advise that you check for the source of water entry.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS

### 30 May 2023 Diag: Bill Quesnel

NORMAL



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 28 Feb 2023 Diag: Kevin Marson

NORMAL



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 26 Oct 2022 Diag: Kevin Marson

ADDITIVES



Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

**WATER**

Area  
**Caster/Basement**  
 Machine Id  
**Cooper Airmist Compressor #3**  
 Component  
**Air Compressor**  
 Fluid  
**PETRO CANADA HYDREX AW 46 (90 GAL)**



## DIAGNOSIS

### Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. Free water present.

### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0850098</b>	WC0824352	WC0796840
Sample Date	Client Info		<b>16 Aug 2023</b>	30 May 2023	28 Feb 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>99999	<b>0</b>	0	0
Iron	ppm	ASTM D5185(m) >50	<b>&lt;1</b>	<1	0
Chromium	ppm	ASTM D5185(m) >4	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m) >4	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >10	<b>&lt;1</b>	<1	0
Lead	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	0
Copper	ppm	ASTM D5185(m) >40	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<b>0</b>	0	<1
Barium	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	0	<1
Calcium	ppm	ASTM D5185(m) 50	<b>&lt;1</b>	0	0
Phosphorus	ppm	ASTM D5185(m) 330	<b>51</b>	53	58
Zinc	ppm	ASTM D5185(m) 430	<b>7</b>	8	9
Sulfur	ppm	ASTM D5185(m) 760	<b>2581</b>	2657	2623
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1


## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	<b>0</b>	0	0
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	<1	<1
Water	%	ASTM D6304* >0.6	<b>0.002</b>	0.00	0.003
ppm Water	ppm	ASTM D6304* >6000	<b>17.5</b>	0.00	25.2


## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 11387</b>	9075	6354
Particles >6µm	ASTM D7647	>2500	<b>▲ 2963</b>	1494	1523
Particles >14µm	ASTM D7647	>320	<b>178</b>	23	108
Particles >21µm	ASTM D7647	>80	<b>39</b>	3	24
Particles >38µm	ASTM D7647	>20	<b>1</b>	0	0
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>▲ 21/19/15</b>	20/18/12	20/18/14


## Particle Trend




## Water




## Additives



## PQ



## Viscosity @ 40°C




## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN) mg KOH/g	ASTM D974*	0.70	<b>0.05</b>	0.09	0.14
<b>VISUAL</b>					
method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE
Appearance	scalar	Visual*	NORML	<b>WGOIL</b>	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	Visual*	>0.6	<b>.2%</b>	NEG
Free Water	scalar	Visual*		<b>1%</b>	NEG

## FLUID PROPERTIES


method	limit/base	current	history1	history2		
Visc @ 40°C	cSt	ASTM D7279(m)	46.4	<b>45.6</b>	45.5	45.6

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



ISO 17025:2017  
Accredited  
Laboratory

### Laboratory

Sample No. : WC0850098

Lab Number : 02576269

Unique Number : 5629329

Test Package : IND 2 ( Additional Tests: KF, PQ )

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 STELCO - BOSC - Basic Oxygen Slab Caster

Received : 16 Aug 2023

Diagnosed : 17 Aug 2023

Diagnostician : Kevin Marson

2330 Regional Road #3, Door: BOSC8

NANTICOKE, ON

CA N0A 1L0

Contact: Tom Walden

Thomas.Walden@stelco.com

T: (519)587-4541

F: (519)587-7702

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.